



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV FR 940 @1300MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 4 SEL75 UV FR 940

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Two LS3872A 64 LED boards, 4000K

[BALLAST] One KTLD-75-UV-PS1400-54-VDIM-LM2 LED driver set to 1300mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	9792
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	149
Total Luminaire Watts	65.6
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	4.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	20627	19858	19839
55	17979	18020	18222
65	14450	15758	16085
75	10487	13467	13618
85	6016	12531	11945

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV FR 940 @1300MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	1217.42	N.A.	12.40
0-30	2588.96	N.A.	26.40
0-40	4239.16	N.A.	43.30
0-60	7430.97	N.A.	75.90
0-80	9263.13	N.A.	94.60
0-90	9617.21	N.A.	98.20
10-90	9302.85	N.A.	95.00
20-40	3021.74	N.A.	30.90
20-50	4714.97	N.A.	48.20
40-70	4320.01	N.A.	44.10
60-80	1832.17	N.A.	18.70
70-80	703.96	N.A.	7.20
80-90	354.08	N.A.	3.60
90-110	174.54	N.A.	1.80
90-120	174.90	N.A.	1.80
90-130	174.90	N.A.	1.80
90-150	174.90	N.A.	1.80
90-180	174.90	N.A.	1.80
110-180	0.35	N.A.	0.00
0-180	9792.11	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	314.36
10-20	903.05
20-30	1371.55
30-40	1650.2
40-50	1693.23
50-60	1498.58
60-70	1128.21
70-80	703.96
80-90	354.08
90-100	141.94
100-110	32.61
110-120	0.35
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV FR 940 @1300MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV FR 940 @1300MA.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	20.9	22.5	21.3	22.9	23.2	22.6	24.2	23.0	24.5	24.9
	3H	22.2	23.7	22.6	24.0	24.4	24.6	26.0	25.0	26.4	26.8
	4H	22.6	24.0	23.0	24.4	24.8	25.4	26.8	25.8	27.2	27.6
	6H	22.8	24.1	23.3	24.5	24.9	26.2	27.5	26.6	27.9	28.3
	8H	22.9	24.1	23.3	24.5	25.0	26.6	27.8	27.0	28.2	28.7
	12H	22.9	24.1	23.4	24.5	25.0	27.0	28.1	27.4	28.5	29.0
4H	2H	21.7	23.1	22.2	23.5	23.9	23.0	24.4	23.5	24.8	25.2
	3H	23.3	24.4	23.7	24.9	25.3	25.3	26.4	25.7	26.9	27.3
	4H	23.8	24.9	24.3	25.3	25.8	26.3	27.3	26.7	27.8	28.3
	6H	24.1	25.1	24.6	25.6	26.1	27.2	28.2	27.7	28.6	29.1
	8H	24.2	25.1	24.7	25.6	26.1	27.7	28.6	28.2	29.0	29.5
	12H	24.3	25.1	24.8	25.6	26.1	28.2	29.0	28.7	29.5	30.0
8H	4H	24.4	25.2	24.8	25.7	26.2	26.5	27.4	27.0	27.8	28.4
	6H	24.9	25.6	25.4	26.1	26.7	27.6	28.4	28.1	28.9	29.4
	8H	25.1	25.7	25.6	26.2	26.8	28.2	28.9	28.7	29.4	29.9
	12H	25.2	25.7	25.7	26.3	26.9	28.8	29.4	29.4	30.0	30.6
12H	4H	24.5	25.3	25.0	25.8	26.3	26.5	27.3	27.0	27.8	28.3
	6H	25.1	25.8	25.7	26.3	26.8	27.7	28.3	28.2	28.8	29.4
	8H	25.3	25.9	25.9	26.5	27.1	28.3	28.9	28.8	29.4	30.0

Maximum UGR = 30.6

POLAR GRAPH



Maximum Candela = 3327.542 Located At Horizontal Angle = 90, Vertical Angle = 3.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (3.5) (Through Max. Cd.)