



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 4 SEL25 UV 940 @400MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-016(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 4 SEL25 UV 940

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] no enclosure.

[LAMPCAT] Two LS3872A 48 LED boards, 4000K

[BALLAST] One KTLD-25-UV-PS450-54-VDIM-LP2 LED driver set to 400mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	3279
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	165
Total Luminaire Watts	19.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.30
Spacing Criterion (90-270)	1.32
Spacing Criterion (Diagonal)	1.42
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	4.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.02 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	7794	7533	7485
55	7662	7308	7106
65	7240	6649	6407
75	6168	5216	4883
85	3464	2342	2105

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 4 SEL25 UV 940 @400MA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	401.02	N.A.	12.20
0-30	858.79	N.A.	26.20
0-40	1421.83	N.A.	43.40
0-60	2572.48	N.A.	78.50
0-80	3226.01	N.A.	98.40
0-90	3278.69	N.A.	100.00
10-90	3175.45	N.A.	96.80
20-40	1020.8	N.A.	31.10
20-50	1619.24	N.A.	49.40
40-70	1573.18	N.A.	48.00
60-80	653.53	N.A.	19.90
70-80	231.00	N.A.	7.00
80-90	52.68	N.A.	1.60
90-110	0.29	N.A.	0.00
90-120	0.29	N.A.	0.00
90-130	0.29	N.A.	0.00
90-150	0.29	N.A.	0.00
90-180	0.29	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	3278.98	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	103.24
10-20	297.78
20-30	457.77
30-40	563.03
40-50	598.43
50-60	552.22
60-70	422.53
70-80	231.00
80-90	52.68
90-100	0.29
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT  
 PHOTOMETRIC FILENAME : ECL G2 4 SEL25 UV 940 @400MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	93	91	88	90	88	86	84
2	99	90	83	78	96	88	82	77	85	79	75	82	77	73	78	75	71	69
3	90	79	71	64	87	77	70	64	74	68	62	72	66	61	69	64	60	58
4	82	70	61	54	80	68	60	54	66	59	53	64	57	52	61	56	52	49
5	75	62	53	46	73	61	53	46	59	51	46	57	50	45	55	49	45	42
6	69	56	47	40	68	55	46	40	53	45	40	51	45	39	50	44	39	37
7	64	51	42	36	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	36	30	25	23

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 4 SEL25 UV 940 @400MA.IES**

**UGR TABLE - CORRECTED**


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	19.1	20.8	19.5	21.1	21.4	19.2	20.9	19.6	21.2	21.5
	3H	20.9	22.4	21.3	22.7	23.1	21.0	22.5	21.4	22.9	23.2
	4H	21.5	22.9	21.9	23.3	23.6	21.6	23.0	22.0	23.4	23.8
	6H	21.9	23.2	22.3	23.6	24.0	22.0	23.3	22.4	23.7	24.1
	8H	22.0	23.2	22.4	23.6	24.0	22.1	23.4	22.5	23.7	24.1
	12H	22.0	23.2	22.4	23.6	24.0	22.1	23.4	22.6	23.7	24.2
4H	2H	19.8	21.2	20.2	21.5	21.9	19.9	21.3	20.3	21.6	22.0
	3H	21.7	22.9	22.1	23.3	23.7	21.8	23.0	22.2	23.4	23.8
	4H	22.5	23.5	22.9	23.9	24.4	22.5	23.6	22.9	24.0	24.4
	6H	23.0	23.9	23.4	24.3	24.8	23.0	23.9	23.5	24.4	24.8
	8H	23.1	24.0	23.5	24.4	24.9	23.1	24.0	23.6	24.5	24.9
	12H	23.1	23.9	23.6	24.4	24.9	23.2	24.0	23.7	24.5	25.0
8H	4H	22.7	23.6	23.2	24.0	24.5	22.8	23.7	23.2	24.1	24.6
	6H	23.3	24.0	23.8	24.5	25.0	23.3	24.1	23.8	24.6	25.0
	8H	23.4	24.1	24.0	24.6	25.1	23.5	24.2	24.0	24.7	25.2
	12H	23.6	24.1	24.1	24.6	25.2	23.6	24.2	24.1	24.7	25.3
12H	4H	22.7	23.5	23.2	24.0	24.5	22.8	23.6	23.3	24.1	24.5
	6H	23.3	24.0	23.8	24.4	25.0	23.4	24.0	23.9	24.5	25.0
	8H	23.5	24.1	24.0	24.6	25.2	23.6	24.2	24.1	24.7	25.2

Maximum UGR = 25.3

POLAR GRAPH



Maximum Candela = 1090.853 Located At Horizontal Angle = 90, Vertical Angle = 2.5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (2.5) (Through Max. Cd.)