



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 4 SEL45 UV FR 930 @700MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 4 SEL45 UV FR 930

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Two LS3872A 48 LED boards, 3000K

[BALLAST] One KTLD-45-UV-PS850-54-VDIM-LM1 LED driver set to 700mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	5271
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	151
Total Luminaire Watts	34.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	4.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	11103	10689	10679
55	9678	9700	9808
65	7778	8482	8658
75	5645	7249	7330
85	3238	6746	6430

**IES INDOOR REPORT****PHOTOMETRIC FILENAME : ECL G2 4 SEL45 UV FR 930 @700MA.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	655.32	N.A.	12.40
0-30	1393.61	N.A.	26.40
0-40	2281.89	N.A.	43.30
0-60	4000.00	N.A.	75.90
0-80	4986.23	N.A.	94.60
0-90	5176.83	N.A.	98.20
10-90	5007.61	N.A.	95.00
20-40	1626.57	N.A.	30.90
20-50	2538.01	N.A.	48.20
40-70	2325.41	N.A.	44.10
60-80	986.23	N.A.	18.70
70-80	378.93	N.A.	7.20
80-90	190.60	N.A.	3.60
90-110	93.95	N.A.	1.80
90-120	94.14	N.A.	1.80
90-130	94.14	N.A.	1.80
90-150	94.14	N.A.	1.80
90-180	94.14	N.A.	1.80
110-180	0.19	N.A.	0.00
0-180	5270.97	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	169.22
10-20	486.10
20-30	738.29
30-40	888.28
40-50	911.44
50-60	806.67
60-70	607.30
70-80	378.93
80-90	190.60
90-100	76.40
100-110	17.55
110-120	0.19
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 4 SEL45 UV FR 930 @700MA.IES

## COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 4 SEL45 UV FR 930 @700MA.IES

## UGR TABLE - CORRECTED


### Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	18.8	20.4	19.2	20.8	21.1	20.5	22.1	20.9	22.4	22.8
	3H	20.1	21.6	20.5	21.9	22.3	22.5	23.9	22.9	24.3	24.7
	4H	20.5	21.9	20.9	22.3	22.7	23.3	24.7	23.7	25.1	25.5
	6H	20.7	22.0	21.2	22.4	22.8	24.1	25.4	24.5	25.8	26.2
	8H	20.8	22.0	21.2	22.4	22.9	24.5	25.7	24.9	26.1	26.6
	12H	20.8	22.0	21.3	22.4	22.9	24.9	26.0	25.3	26.4	26.9
4H	2H	19.6	21.0	20.1	21.4	21.8	20.9	22.3	21.4	22.7	23.1
	3H	21.2	22.3	21.6	22.8	23.2	23.2	24.3	23.6	24.8	25.2
	4H	21.7	22.8	22.2	23.2	23.7	24.2	25.2	24.6	25.7	26.2
	6H	22.0	23.0	22.5	23.5	24.0	25.1	26.1	25.6	26.5	27.0
	8H	22.1	23.0	22.6	23.5	24.0	25.6	26.5	26.1	26.9	27.4
	12H	22.2	23.0	22.7	23.5	24.0	26.1	26.9	26.6	27.4	27.9
8H	4H	22.3	23.1	22.7	23.6	24.1	24.4	25.3	24.9	25.7	26.3
	6H	22.8	23.5	23.3	24.0	24.6	25.5	26.3	26.0	26.8	27.3
	8H	23.0	23.6	23.5	24.1	24.7	26.1	26.8	26.6	27.3	27.8
	12H	23.1	23.6	23.6	24.2	24.8	26.7	27.3	27.3	27.9	28.5
12H	4H	22.4	23.2	22.9	23.7	24.2	24.4	25.2	24.9	25.7	26.2
	6H	23.0	23.7	23.6	24.2	24.7	25.6	26.2	26.1	26.7	27.3
	8H	23.2	23.8	23.8	24.4	25.0	26.2	26.8	26.7	27.3	27.9

Maximum UGR = 28.5

POLAR GRAPH



Maximum Candela = 1791.176 Located At Horizontal Angle = 90, Vertical Angle = 3.5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (3.5) (Through Max. Cd.)