



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV 940 @1200MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-016(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 4 SEL75 UV 940

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] no enclosure.

[LAMPCAT] Two LS3872A 64 LED boards, 4000K

[BALLAST] One KTLD-75-UV-PS1400-54-VDIM-LM2 LED driver set to 1200mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	9592
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	159
Total Luminaire Watts	60.2
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.30
Spacing Criterion (90-270)	1.32
Spacing Criterion (Diagonal)	1.42
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	4.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.02 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	22799	22035	21895
55	22412	21377	20788
65	21180	19450	18742
75	18043	15260	14285
85	10133	6852	6159

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV 940 @1200MA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	1173.1	N.A.	12.20
0-30	2512.19	N.A.	26.20
0-40	4159.21	N.A.	43.40
0-60	7525.17	N.A.	78.50
0-80	9436.91	N.A.	98.40
0-90	9591.02	N.A.	100.00
10-90	9289.02	N.A.	96.80
20-40	2986.12	N.A.	31.10
20-50	4736.69	N.A.	49.40
40-70	4601.95	N.A.	48.00
60-80	1911.75	N.A.	19.90
70-80	675.75	N.A.	7.00
80-90	154.11	N.A.	1.60
90-110	0.84	N.A.	0.00
90-120	0.84	N.A.	0.00
90-130	0.84	N.A.	0.00
90-150	0.84	N.A.	0.00
90-180	0.84	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	9591.86	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	302.00
10-20	871.09
20-30	1339.1
30-40	1647.02
40-50	1750.57
50-60	1615.38
60-70	1236.00
70-80	675.75
80-90	154.11
90-100	0.84
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV 940 @1200MA.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	93	91	88	90	88	86	84
2	99	90	83	78	96	88	82	77	85	79	75	82	77	73	78	75	71	69
3	90	79	71	64	87	77	70	64	74	68	62	72	66	61	69	64	60	58
4	82	70	61	54	80	68	60	54	66	59	53	64	57	52	61	56	52	49
5	75	62	53	46	73	61	53	46	59	51	46	57	50	45	55	49	45	42
6	69	56	47	40	68	55	46	40	53	45	40	51	45	39	50	44	39	37
7	64	51	42	36	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	36	30	25	23

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV 940 @1200MA.IES**

**UGR TABLE - CORRECTED**


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	22.9	24.6	23.3	24.9	25.2	23.0	24.7	23.4	25.0	25.3
	3H	24.7	26.2	25.1	26.5	26.9	24.8	26.3	25.2	26.7	27.0
	4H	25.3	26.7	25.7	27.1	27.4	25.4	26.8	25.8	27.2	27.6
	6H	25.7	27.0	26.1	27.4	27.8	25.8	27.1	26.2	27.5	27.9
	8H	25.8	27.0	26.2	27.4	27.8	25.9	27.2	26.3	27.5	27.9
	12H	25.8	27.0	26.2	27.4	27.8	25.9	27.2	26.4	27.5	28.0
4H	2H	23.6	25.0	24.0	25.3	25.7	23.7	25.1	24.1	25.4	25.8
	3H	25.5	26.7	25.9	27.1	27.5	25.6	26.8	26.0	27.2	27.6
	4H	26.3	27.3	26.7	27.7	28.2	26.3	27.4	26.7	27.8	28.2
	6H	26.8	27.7	27.2	28.1	28.6	26.8	27.7	27.3	28.2	28.6
	8H	26.9	27.7	27.3	28.2	28.7	26.9	27.8	27.4	28.3	28.7
	12H	26.9	27.7	27.4	28.2	28.7	27.0	27.8	27.5	28.3	28.8
8H	4H	26.5	27.4	27.0	27.8	28.3	26.6	27.5	27.0	27.9	28.4
	6H	27.1	27.8	27.6	28.3	28.8	27.1	27.9	27.6	28.4	28.8
	8H	27.2	27.9	27.8	28.4	28.9	27.3	28.0	27.8	28.5	29.0
	12H	27.4	27.9	27.9	28.4	29.0	27.4	28.0	27.9	28.5	29.1
12H	4H	26.5	27.3	27.0	27.8	28.3	26.6	27.4	27.1	27.9	28.3
	6H	27.1	27.8	27.6	28.2	28.8	27.2	27.8	27.7	28.3	28.8
	8H	27.3	27.9	27.8	28.4	29.0	27.4	28.0	27.9	28.5	29.0

Maximum UGR = 29.1

POLAR GRAPH



Maximum Candela = 3191.025 Located At Horizontal Angle = 90, Vertical Angle = 2.5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (2.5) (Through Max. Cd.)