



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV FR 935 @1400MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 4 SEL75 UV FR 935

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Two LS3872A 64 LED boards, 3500K

[BALLAST] One KTLD-75-UV-PS1400-54-VDIM-LM2 LED driver set to 1400mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	10187
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	143
Total Luminaire Watts	71.1
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	4.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	21458	20658	20639
55	18703	18746	18956
65	15033	16393	16733
75	10910	14010	14167
85	6258	13037	12426

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV FR 935 @1400MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	1266.48	N.A.	12.40
0-30	2693.3	N.A.	26.40
0-40	4410.00	N.A.	43.30
0-60	7730.45	N.A.	75.90
0-80	9636.45	N.A.	94.60
0-90	10004.8	N.A.	98.20
10-90	9677.77	N.A.	95.00
20-40	3143.52	N.A.	30.90
20-50	4904.99	N.A.	48.20
40-70	4494.12	N.A.	44.10
60-80	1906.00	N.A.	18.70
70-80	732.33	N.A.	7.20
80-90	368.35	N.A.	3.60
90-110	181.58	N.A.	1.80
90-120	181.95	N.A.	1.80
90-130	181.95	N.A.	1.80
90-150	181.95	N.A.	1.80
90-180	181.95	N.A.	1.80
110-180	0.37	N.A.	0.00
0-180	10186.74	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	327.03
10-20	939.45
20-30	1426.82
30-40	1716.7
40-50	1761.47
50-60	1558.97
60-70	1173.68
70-80	732.33
80-90	368.35
90-100	147.66
100-110	33.92
110-120	0.37
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV FR 935 @1400MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23


IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 4 SEL75 UV FR 935 @1400MA.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	21.1	22.7	21.5	23.1	23.4	22.8	24.4	23.2	24.7	25.1
	3H	22.4	23.9	22.8	24.2	24.6	24.8	26.2	25.2	26.6	27.0
	4H	22.8	24.2	23.2	24.6	25.0	25.6	27.0	26.0	27.4	27.8
	6H	23.0	24.3	23.5	24.7	25.1	26.4	27.7	26.8	28.1	28.5
	8H	23.1	24.3	23.5	24.7	25.2	26.8	28.0	27.2	28.4	28.9
	12H	23.1	24.3	23.6	24.7	25.2	27.2	28.3	27.6	28.7	29.2
4H	2H	21.9	23.3	22.4	23.7	24.1	23.2	24.6	23.7	25.0	25.4
	3H	23.5	24.6	23.9	25.1	25.5	25.5	26.6	25.9	27.1	27.5
	4H	24.0	25.1	24.5	25.5	26.0	26.5	27.5	26.9	28.0	28.5
	6H	24.3	25.3	24.8	25.8	26.3	27.4	28.4	27.9	28.8	29.3
	8H	24.4	25.3	24.9	25.8	26.3	27.9	28.8	28.4	29.2	29.7
	12H	24.5	25.3	25.0	25.8	26.3	28.4	29.2	28.9	29.7	30.2
8H	4H	24.6	25.4	25.0	25.9	26.4	26.7	27.6	27.2	28.0	28.6
	6H	25.1	25.8	25.6	26.3	26.9	27.8	28.6	28.3	29.1	29.6
	8H	25.3	25.9	25.8	26.4	27.0	28.4	29.1	28.9	29.6	30.1
	12H	25.4	25.9	25.9	26.5	27.1	29.0	29.6	29.6	30.2	30.8
12H	4H	24.7	25.5	25.2	26.0	26.5	26.7	27.5	27.2	28.0	28.5
	6H	25.3	26.0	25.9	26.5	27.0	27.9	28.5	28.4	29.0	29.6
	8H	25.5	26.1	26.1	26.7	27.3	28.5	29.1	29.0	29.6	30.2

Maximum UGR = 30.8

POLAR GRAPH



Maximum Candela = 3461.647 Located At Horizontal Angle = 90, Vertical Angle = 3.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (3.5) (Through Max. Cd.)