



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 6 SEL75 UV FR 935 @1100MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 6 SEL75 UV FR 935

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Three LS3872A 48 LED boards, 3500K

[BALLAST] One KTLD-75-UV-PS1400-54-VDIM-LM2 LED driver set to 1100mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	8300
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	153
Total Luminaire Watts	54.3
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	6.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	11717	11259	11211
55	10235	10229	10297
65	8256	8961	9090
75	6038	7682	7696
85	3582	7205	6750

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 6 SEL75 UV FR 935 @1100MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	1031.94	N.A.	12.40
0-30	2194.53	N.A.	26.40
0-40	3593.32	N.A.	43.30
0-60	6298.85	N.A.	75.90
0-80	7851.88	N.A.	94.60
0-90	8152.01	N.A.	98.20
10-90	7885.54	N.A.	95.00
20-40	2561.37	N.A.	30.90
20-50	3996.64	N.A.	48.20
40-70	3661.85	N.A.	44.10
60-80	1553.03	N.A.	18.70
70-80	596.71	N.A.	7.20
80-90	300.14	N.A.	3.60
90-110	147.95	N.A.	1.80
90-120	148.25	N.A.	1.80
90-130	148.25	N.A.	1.80
90-150	148.25	N.A.	1.80
90-180	148.25	N.A.	1.80
110-180	0.30	N.A.	0.00
0-180	8300.26	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	266.47
10-20	765.47
20-30	1162.59
30-40	1398.79
40-50	1435.26
50-60	1270.27
60-70	956.32
70-80	596.71
80-90	300.14
90-100	120.31
100-110	27.64
110-120	0.30
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 6 SEL75 UV FR 935 @1100MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23


IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 6 SEL75 UV FR 935 @1100MA.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	19.0	20.6	19.4	21.0	21.3	20.7	22.3	21.1	22.7	23.0
	3H	20.3	21.8	20.7	22.1	22.5	22.7	24.1	23.1	24.5	24.9
	4H	20.7	22.1	21.1	22.5	22.9	23.5	24.9	24.0	25.3	25.7
	6H	20.9	22.2	21.4	22.6	23.0	24.3	25.6	24.8	26.0	26.5
	8H	21.0	22.2	21.4	22.6	23.1	24.7	25.9	25.2	26.4	26.8
	12H	21.0	22.2	21.5	22.6	23.1	25.1	26.3	25.6	26.7	27.2
4H	2H	19.8	21.2	20.3	21.6	22.0	21.2	22.5	21.6	22.9	23.4
	3H	21.4	22.5	21.8	23.0	23.4	23.4	24.5	23.8	25.0	25.4
	4H	21.9	23.0	22.4	23.4	23.9	24.4	25.4	24.9	25.9	26.4
	6H	22.3	23.2	22.7	23.7	24.2	25.4	26.3	25.8	26.8	27.3
	8H	22.3	23.2	22.8	23.7	24.2	25.8	26.7	26.3	27.2	27.7
	12H	22.4	23.2	22.9	23.7	24.2	26.3	27.1	26.8	27.6	28.1
8H	4H	22.5	23.3	23.0	23.8	24.3	24.6	25.5	25.1	26.0	26.5
	6H	23.0	23.7	23.5	24.2	24.8	25.8	26.5	26.3	27.0	27.5
	8H	23.2	23.8	23.7	24.4	24.9	26.4	27.0	26.9	27.5	28.1
	12H	23.3	23.9	23.8	24.4	25.0	27.0	27.6	27.5	28.1	28.7
12H	4H	22.6	23.4	23.1	23.9	24.4	24.6	25.4	25.1	25.9	26.4
	6H	23.2	23.9	23.8	24.4	24.9	25.8	26.5	26.4	27.0	27.6
	8H	23.4	24.0	24.0	24.6	25.2	26.5	27.0	27.0	27.6	28.2

Maximum UGR = 28.7

POLAR GRAPH



Maximum Candela = 2820.585 Located At Horizontal Angle = 90, Vertical Angle = 3.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (3.5) (Through Max. Cd.)