



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 6 SEL100 UV FR 930 @1800MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 6 SEL100 UV FR 930

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Three LS3872A 68 LED boards, 3000K

[BALLAST] One KTLD-100-UV-PS1800-54-VDIM-LM2 LED driver set to 1800mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	13315
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	147
Total Luminaire Watts	90.3
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	6.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	18795	18061	17984
55	16418	16409	16518
65	13243	14374	14581
75	9686	12323	12345
85	5745	11557	10828

IES INDOOR REPORT**PHOTOMETRIC FILENAME : ECL G2 6 SEL100 UV FR 930 @1800MA.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	1655.37	N.A.	12.40
0-30	3520.32	N.A.	26.40
0-40	5764.15	N.A.	43.30
0-60	10104.18	N.A.	75.90
0-80	12595.44	N.A.	94.60
0-90	13076.9	N.A.	98.20
10-90	12649.44	N.A.	95.00
20-40	4108.78	N.A.	30.90
20-50	6411.13	N.A.	48.20
40-70	5874.09	N.A.	44.10
60-80	2491.27	N.A.	18.70
70-80	957.20	N.A.	7.20
80-90	481.46	N.A.	3.60
90-110	237.33	N.A.	1.80
90-120	237.81	N.A.	1.80
90-130	237.81	N.A.	1.80
90-150	237.81	N.A.	1.80
90-180	237.81	N.A.	1.80
110-180	0.48	N.A.	0.00
0-180	13314.71	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	427.45
10-20	1227.92
20-30	1864.95
30-40	2243.84
40-50	2302.35
50-60	2037.68
60-70	1534.07
70-80	957.20
80-90	481.46
90-100	193.00
100-110	44.34
110-120	0.48
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 6 SEL100 UV FR 930 @1800MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23


IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 6 SEL100 UV FR 930 @1800MA.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	20.6	22.2	21.0	22.6	22.9	22.3	23.9	22.7	24.3	24.6
	3H	21.9	23.4	22.3	23.7	24.1	24.3	25.7	24.7	26.1	26.5
	4H	22.3	23.7	22.7	24.1	24.5	25.1	26.5	25.6	26.9	27.3
	6H	22.5	23.8	23.0	24.2	24.6	25.9	27.2	26.4	27.6	28.1
	8H	22.6	23.8	23.0	24.2	24.7	26.3	27.5	26.8	28.0	28.4
	12H	22.6	23.8	23.1	24.2	24.7	26.7	27.9	27.2	28.3	28.8
4H	2H	21.4	22.8	21.9	23.2	23.6	22.8	24.1	23.2	24.5	25.0
	3H	23.0	24.1	23.4	24.6	25.0	25.0	26.1	25.4	26.6	27.0
	4H	23.5	24.6	24.0	25.0	25.5	26.0	27.0	26.5	27.5	28.0
	6H	23.9	24.8	24.3	25.3	25.8	27.0	27.9	27.4	28.4	28.9
	8H	23.9	24.8	24.4	25.3	25.8	27.4	28.3	27.9	28.8	29.3
	12H	24.0	24.8	24.5	25.3	25.8	27.9	28.7	28.4	29.2	29.7
8H	4H	24.1	24.9	24.6	25.4	25.9	26.2	27.1	26.7	27.6	28.1
	6H	24.6	25.3	25.1	25.8	26.4	27.4	28.1	27.9	28.6	29.1
	8H	24.8	25.4	25.3	26.0	26.5	28.0	28.6	28.5	29.1	29.7
	12H	24.9	25.5	25.4	26.0	26.6	28.6	29.2	29.1	29.7	30.3
12H	4H	24.2	25.0	24.7	25.5	26.0	26.2	27.0	26.7	27.5	28.0
	6H	24.8	25.5	25.4	26.0	26.5	27.4	28.1	28.0	28.6	29.2
	8H	25.0	25.6	25.6	26.2	26.8	28.1	28.6	28.6	29.2	29.8

Maximum UGR = 30.3

POLAR GRAPH



Maximum Candela = 4524.589 Located At Horizontal Angle = 90, Vertical Angle = 3.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (3.5) (Through Max. Cd.)