



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 6 SEL25 UV FR 935 @300MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 6 SEL25 UV FR 935

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Three LS3872A 28 LED boards, 3500K

[BALLAST] One KTLD-25-UV-PS450-54-VDIM-LP2 LED driver set to 300mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1995
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	153
Total Luminaire Watts	13
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	6.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2817	2707	2695
55	2461	2459	2475
65	1985	2154	2185
75	1452	1847	1850
85	861	1732	1623

IES INDOOR REPORT**PHOTOMETRIC FILENAME : ECL G2 6 SEL25 UV FR 935 @300MA.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	248.09	N.A.	12.40
0-30	527.58	N.A.	26.40
0-40	863.86	N.A.	43.30
0-60	1514.29	N.A.	75.90
0-80	1887.66	N.A.	94.60
0-90	1959.81	N.A.	98.20
10-90	1895.75	N.A.	95.00
20-40	615.78	N.A.	30.90
20-50	960.82	N.A.	48.20
40-70	880.34	N.A.	44.10
60-80	373.36	N.A.	18.70
70-80	143.45	N.A.	7.20
80-90	72.15	N.A.	3.60
90-110	35.57	N.A.	1.80
90-120	35.64	N.A.	1.80
90-130	35.64	N.A.	1.80
90-150	35.64	N.A.	1.80
90-180	35.64	N.A.	1.80
110-180	0.07	N.A.	0.00
0-180	1995.45	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	64.06
10-20	184.03
20-30	279.50
30-40	336.28
40-50	345.05
50-60	305.38
60-70	229.91
70-80	143.45
80-90	72.15
90-100	28.92
100-110	6.64
110-120	0.07
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 6 SEL25 UV FR 935 @300MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	26	36	30	25	35	29	25	23

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 6 SEL25 UV FR 935 @300MA.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	14.0	15.6	14.4	16.0	16.3	15.7	17.3	16.1	17.7	18.0
	3H	15.3	16.8	15.7	17.1	17.5	17.7	19.1	18.1	19.5	19.9
	4H	15.7	17.1	16.1	17.5	17.9	18.5	19.9	19.0	20.3	20.7
	6H	15.9	17.2	16.4	17.6	18.0	19.3	20.6	19.8	21.0	21.5
	8H	16.0	17.2	16.4	17.6	18.1	19.7	20.9	20.2	21.4	21.8
	12H	16.0	17.2	16.5	17.6	18.1	20.1	21.3	20.6	21.7	22.2
4H	2H	14.8	16.2	15.3	16.6	17.0	16.2	17.5	16.6	17.9	18.4
	3H	16.4	17.5	16.8	18.0	18.4	18.4	19.5	18.8	20.0	20.4
	4H	16.9	18.0	17.4	18.4	18.9	19.4	20.4	19.9	20.9	21.4
	6H	17.3	18.2	17.7	18.7	19.2	20.4	21.3	20.8	21.8	22.3
	8H	17.3	18.2	17.8	18.7	19.2	20.8	21.7	21.3	22.2	22.7
	12H	17.4	18.2	17.9	18.7	19.2	21.3	22.1	21.8	22.6	23.1
8H	4H	17.5	18.3	18.0	18.8	19.3	19.6	20.5	20.1	21.0	21.5
	6H	18.0	18.7	18.5	19.2	19.8	20.8	21.5	21.3	22.0	22.5
	8H	18.2	18.8	18.7	19.4	19.9	21.4	22.0	21.9	22.5	23.1
	12H	18.3	18.9	18.8	19.4	20.0	22.0	22.6	22.5	23.1	23.7
12H	4H	17.6	18.4	18.1	18.9	19.4	19.6	20.4	20.1	20.9	21.4
	6H	18.2	18.9	18.8	19.4	19.9	20.8	21.5	21.4	22.0	22.6
	8H	18.4	19.0	19.0	19.6	20.2	21.5	22.0	22.0	22.6	23.2

Maximum UGR = 23.7

POLAR GRAPH



Maximum Candela = 678.092 Located At Horizontal Angle = 90, Vertical Angle = 3.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (3.5) (Through Max. Cd.)