



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 6 SEL35 UV FR 930 @650MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 6 SEL35 UV FR 930

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Three LS3872A 28 LED boards, 3000K

[BALLAST] One KTLD-35-UV-PS650-54-VDIM-LM1 LED driver set to 650mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4295
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	154
Total Luminaire Watts	27.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	6.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	6063	5826	5801
55	5296	5293	5328
65	4272	4636	4703
75	3124	3975	3982
85	1853	3728	3493

**IES INDOOR REPORT****PHOTOMETRIC FILENAME : ECL G2 6 SEL35 UV FR 930 @650MA.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	533.96	N.A.	12.40
0-30	1135.51	N.A.	26.40
0-40	1859.28	N.A.	43.30
0-60	3259.2	N.A.	75.90
0-80	4062.78	N.A.	94.60
0-90	4218.08	N.A.	98.20
10-90	4080.2	N.A.	95.00
20-40	1325.33	N.A.	30.90
20-50	2067.97	N.A.	48.20
40-70	1894.74	N.A.	44.10
60-80	803.58	N.A.	18.70
70-80	308.75	N.A.	7.20
80-90	155.30	N.A.	3.60
90-110	76.55	N.A.	1.80
90-120	76.71	N.A.	1.80
90-130	76.71	N.A.	1.80
90-150	76.71	N.A.	1.80
90-180	76.71	N.A.	1.80
110-180	0.16	N.A.	0.00
0-180	4294.79	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	137.88
10-20	396.08
20-30	601.56
30-40	723.77
40-50	742.64
50-60	657.27
60-70	494.83
70-80	308.75
80-90	155.30
90-100	62.25
100-110	14.30
110-120	0.16
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 6 SEL35 UV FR 930 @650MA.IES

## COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 6 SEL35 UV FR 930 @650MA.IES

## UGR TABLE - CORRECTED


### Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	16.7	18.3	17.1	18.7	19.0	18.4	20.0	18.8	20.4	20.7
	3H	18.0	19.5	18.4	19.8	20.2	20.4	21.8	20.8	22.2	22.6
	4H	18.4	19.8	18.8	20.2	20.6	21.2	22.6	21.7	23.0	23.4
	6H	18.6	19.9	19.1	20.3	20.7	22.0	23.3	22.5	23.7	24.2
	8H	18.7	19.9	19.1	20.3	20.8	22.4	23.6	22.9	24.1	24.5
	12H	18.7	19.9	19.2	20.3	20.8	22.8	24.0	23.3	24.4	24.9
4H	2H	17.5	18.9	18.0	19.3	19.7	18.9	20.2	19.3	20.6	21.1
	3H	19.1	20.2	19.5	20.7	21.1	21.1	22.2	21.5	22.7	23.1
	4H	19.6	20.7	20.1	21.1	21.6	22.1	23.1	22.6	23.6	24.1
	6H	20.0	20.9	20.4	21.4	21.9	23.1	24.0	23.5	24.5	25.0
	8H	20.0	20.9	20.5	21.4	21.9	23.5	24.4	24.0	24.9	25.4
	12H	20.1	20.9	20.6	21.4	21.9	24.0	24.8	24.5	25.3	25.8
8H	4H	20.2	21.0	20.7	21.5	22.0	22.3	23.2	22.8	23.7	24.2
	6H	20.7	21.4	21.2	21.9	22.5	23.5	24.2	24.0	24.7	25.2
	8H	20.9	21.5	21.4	22.1	22.6	24.1	24.7	24.6	25.2	25.8
	12H	21.0	21.6	21.5	22.1	22.7	24.7	25.3	25.2	25.8	26.4
12H	4H	20.3	21.1	20.8	21.6	22.1	22.3	23.1	22.8	23.6	24.1
	6H	20.9	21.6	21.5	22.1	22.6	23.5	24.2	24.1	24.7	25.3
	8H	21.1	21.7	21.7	22.3	22.9	24.2	24.7	24.7	25.3	25.9

Maximum UGR = 26.4

POLAR GRAPH



Maximum Candela = 1459.449 Located At Horizontal Angle = 90, Vertical Angle = 3.5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (3.5) (Through Max. Cd.)