



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 8 SEL15 UV 930 @300MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-016(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 8 SEL15 UV 930

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] no enclosure.

[LAMPCAT] Four LS3872A 28 LED boards, 3000K

[BALLAST] One KTLD-15-UV-PS300-54-VDIM-LP1 LED driver set at 300mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2081
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	155
Total Luminaire Watts	13.4
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.30
Spacing Criterion (90-270)	1.32
Spacing Criterion (Diagonal)	1.42
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	8.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.02 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2479	2394	2375
55	2440	2324	2255
65	2310	2117	2033
75	1976	1665	1549
85	1131	754	668

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 8 SEL15 UV 930 @300MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	254.48	N.A.	12.20
0-30	544.96	N.A.	26.20
0-40	902.25	N.A.	43.40
0-60	1632.41	N.A.	78.50
0-80	2047.12	N.A.	98.40
0-90	2080.55	N.A.	100.00
10-90	2015.04	N.A.	96.80
20-40	647.77	N.A.	31.10
20-50	1027.52	N.A.	49.40
40-70	998.29	N.A.	48.00
60-80	414.71	N.A.	19.90
70-80	146.59	N.A.	7.00
80-90	33.43	N.A.	1.60
90-110	0.18	N.A.	0.00
90-120	0.18	N.A.	0.00
90-130	0.18	N.A.	0.00
90-150	0.18	N.A.	0.00
90-180	0.18	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	2080.74	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	65.51
10-20	188.96
20-30	290.49
30-40	357.28
40-50	379.75
50-60	350.42
60-70	268.12
70-80	146.59
80-90	33.43
90-100	0.18
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 8 SEL15 UV 930 @300MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	93	91	88	90	88	86	84
2	99	90	83	78	96	88	82	77	85	79	75	82	77	73	78	75	71	69
3	90	79	71	64	87	77	70	64	74	68	62	72	66	61	69	64	60	58
4	82	70	61	54	80	68	60	54	66	59	53	64	57	52	61	56	52	49
5	75	62	53	46	73	61	53	46	59	51	46	57	50	45	55	49	45	42
6	69	56	47	40	67	55	46	40	53	45	40	51	45	39	50	44	39	37
7	64	51	42	35	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	36	30	25	23


IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL G2 8 SEL15 UV 930 @300MA.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	15.2	16.9	15.6	17.2	17.5	15.3	17.0	15.7	17.3	17.6
	3H	17.0	18.5	17.4	18.8	19.2	17.1	18.6	17.5	19.0	19.3
	4H	17.6	19.0	18.0	19.4	19.7	17.7	19.1	18.1	19.5	19.9
	6H	18.0	19.3	18.4	19.7	20.1	18.1	19.4	18.5	19.8	20.2
	8H	18.1	19.3	18.5	19.7	20.1	18.2	19.5	18.7	19.9	20.3
	12H	18.1	19.3	18.5	19.7	20.1	18.3	19.5	18.7	19.9	20.3
4H	2H	15.9	17.3	16.3	17.6	18.0	16.0	17.4	16.4	17.7	18.1
	3H	17.8	19.0	18.2	19.4	19.8	17.9	19.1	18.3	19.5	19.9
	4H	18.6	19.6	19.0	20.0	20.5	18.6	19.7	19.1	20.1	20.5
	6H	19.0	20.0	19.5	20.4	20.9	19.1	20.1	19.6	20.5	20.9
	8H	19.2	20.0	19.6	20.5	21.0	19.3	20.1	19.7	20.6	21.0
	12H	19.2	20.0	19.7	20.5	21.0	19.3	20.1	19.8	20.6	21.1
8H	4H	18.8	19.7	19.3	20.1	20.6	18.9	19.8	19.3	20.2	20.7
	6H	19.4	20.1	19.9	20.6	21.1	19.5	20.2	20.0	20.7	21.1
	8H	19.5	20.2	20.1	20.7	21.2	19.6	20.3	20.1	20.8	21.3
	12H	19.6	20.2	20.2	20.7	21.3	19.8	20.3	20.3	20.8	21.4
12H	4H	18.8	19.6	19.3	20.1	20.6	18.9	19.7	19.4	20.2	20.6
	6H	19.4	20.1	19.9	20.5	21.1	19.5	20.1	20.0	20.6	21.1
	8H	19.6	20.2	20.1	20.7	21.2	19.7	20.3	20.2	20.8	21.3

Maximum UGR = 21.4

POLAR GRAPH



Maximum Candela = 692.22 Located At Horizontal Angle = 90, Vertical Angle = 2.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (2.5) (Through Max. Cd.)