



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 8 SEL25 UV FR 930 @450MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 8 SEL25 UV FR 930

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Four LS3872A 48 LED boards, 3000K

[BALLAST] One KTLD-25-UV-PS450-54-VDIM-LP2 LED driver set to 450mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	3392
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	154
Total Luminaire Watts	22
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	8.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	3601	3457	3436
55	3149	3142	3156
65	2544	2755	2786
75	1868	2366	2359
85	1128	2228	2069

IES INDOOR REPORT**PHOTOMETRIC FILENAME : ECL G2 8 SEL25 UV FR 930 @450MA.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	421.73	N.A.	12.40
0-30	896.85	N.A.	26.40
0-40	1468.5	N.A.	43.30
0-60	2574.18	N.A.	75.90
0-80	3208.87	N.A.	94.60
0-90	3331.53	N.A.	98.20
10-90	3222.63	N.A.	95.00
20-40	1046.77	N.A.	30.90
20-50	1633.33	N.A.	48.20
40-70	1496.51	N.A.	44.10
60-80	634.69	N.A.	18.70
70-80	243.86	N.A.	7.20
80-90	122.66	N.A.	3.60
90-110	60.46	N.A.	1.80
90-120	60.59	N.A.	1.80
90-130	60.59	N.A.	1.80
90-150	60.59	N.A.	1.80
90-180	60.59	N.A.	1.80
110-180	0.12	N.A.	0.00
0-180	3392.12	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	108.90
10-20	312.83
20-30	475.12
30-40	571.65
40-50	586.56
50-60	519.13
60-70	390.83
70-80	243.86
80-90	122.66
90-100	49.17
100-110	11.30
110-120	0.12
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 8 SEL25 UV FR 930 @450MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 8 SEL25 UV FR 930 @450MA.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	14.8	16.4	15.2	16.8	17.1	16.5	18.1	16.9	18.5	18.8
	3H	16.1	17.6	16.5	17.9	18.3	18.5	20.0	18.9	20.3	20.7
	4H	16.5	17.9	16.9	18.3	18.7	19.3	20.7	19.8	21.1	21.5
	6H	16.7	18.0	17.2	18.4	18.8	20.1	21.4	20.6	21.8	22.3
	8H	16.8	18.0	17.2	18.4	18.9	20.5	21.8	21.0	22.2	22.6
	12H	16.8	18.0	17.3	18.4	18.9	20.9	22.1	21.4	22.5	23.0
4H	2H	15.6	17.0	16.1	17.4	17.8	17.0	18.4	17.4	18.7	19.2
	3H	17.2	18.4	17.6	18.8	19.2	19.2	20.4	19.6	20.8	21.2
	4H	17.7	18.8	18.2	19.2	19.7	20.2	21.3	20.7	21.7	22.2
	6H	18.1	19.0	18.5	19.5	20.0	21.2	22.1	21.7	22.6	23.1
	8H	18.1	19.0	18.6	19.5	20.0	21.6	22.5	22.1	23.0	23.5
	12H	18.2	19.0	18.7	19.5	20.0	22.2	22.9	22.7	23.5	24.0
8H	4H	18.3	19.1	18.8	19.6	20.1	20.4	21.3	20.9	21.8	22.3
	6H	18.8	19.5	19.3	20.0	20.6	21.6	22.3	22.1	22.8	23.4
	8H	19.0	19.6	19.5	20.2	20.7	22.2	22.8	22.7	23.4	23.9
	12H	19.1	19.7	19.6	20.2	20.8	22.8	23.4	23.4	23.9	24.5
12H	4H	18.4	19.2	18.9	19.7	20.2	20.4	21.2	21.0	21.8	22.3
	6H	19.0	19.7	19.6	20.2	20.8	21.7	22.3	22.2	22.8	23.4
	8H	19.3	19.8	19.8	20.4	21.0	22.3	22.9	22.8	23.4	24.0

Maximum UGR = 24.5

POLAR GRAPH



Maximum Candela = 1152.704 Located At Horizontal Angle = 90, Vertical Angle = 3.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (3.5) (Through Max. Cd.)