



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL G2 8 SEL75 UV FR 935 @1200MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/5/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL G2 8 SEL75 UV FR 935

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Four LS3872A 48 LED boards, 3500K

[BALLAST] One KTLD-75-UV-PS1400-54-VDIM-LM2 LED driver set to 1200mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	9120
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	156
Total Luminaire Watts	58.6
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	8.00 ft
Luminous Width (90-270)	0.38 ft
Luminous Height	0.06 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	9681	9293	9239
55	8466	8448	8485
65	6841	7407	7491
75	5023	6360	6342
85	3033	5989	5563

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 8 SEL75 UV FR 935 @1200MA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	1133.86	N.A.	12.40
0-30	2411.26	N.A.	26.40
0-40	3948.2	N.A.	43.30
0-60	6920.93	N.A.	75.90
0-80	8627.34	N.A.	94.60
0-90	8957.11	N.A.	98.20
10-90	8664.33	N.A.	95.00
20-40	2814.34	N.A.	30.90
20-50	4391.35	N.A.	48.20
40-70	4023.5	N.A.	44.10
60-80	1706.41	N.A.	18.70
70-80	655.64	N.A.	7.20
80-90	329.78	N.A.	3.60
90-110	162.56	N.A.	1.80
90-120	162.89	N.A.	1.80
90-130	162.89	N.A.	1.80
90-150	162.89	N.A.	1.80
90-180	162.89	N.A.	1.80
110-180	0.33	N.A.	0.00
0-180	9120.00	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	292.79
10-20	841.07
20-30	1277.41
30-40	1536.93
40-50	1577.01
50-60	1395.72
60-70	1050.77
70-80	655.64
80-90	329.78
90-100	132.19
100-110	30.37
110-120	0.33
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 8 SEL75 UV FR 935 @1200MA.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	77	69	63	73	67	61	70	65	60	67	63	59	56
4	82	69	60	54	79	68	60	53	65	58	52	63	56	51	60	55	50	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	48	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	51	42	36	62	50	41	35	48	40	35	46	40	35	45	39	34	32
8	60	46	38	32	58	45	37	32	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL G2 8 SEL75 UV FR 935 @1200MA.IES**

**UGR TABLE - CORRECTED**


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	18.3	19.9	18.7	20.3	20.6	20.0	21.6	20.4	22.0	22.3
	3H	19.6	21.1	20.0	21.4	21.8	22.0	23.5	22.4	23.8	24.2
	4H	20.0	21.4	20.4	21.8	22.2	22.8	24.2	23.3	24.6	25.0
	6H	20.2	21.5	20.7	21.9	22.4	23.6	24.9	24.1	25.3	25.8
	8H	20.3	21.5	20.7	21.9	22.4	24.0	25.3	24.5	25.7	26.1
	12H	20.3	21.5	20.8	21.9	22.4	24.4	25.6	24.9	26.0	26.5
4H	2H	19.1	20.5	19.6	20.9	21.3	20.5	21.9	20.9	22.2	22.7
	3H	20.7	21.9	21.1	22.3	22.7	22.7	23.9	23.1	24.3	24.7
	4H	21.2	22.3	21.7	22.7	23.2	23.7	24.8	24.2	25.2	25.7
	6H	21.6	22.5	22.0	23.0	23.5	24.7	25.6	25.2	26.1	26.6
	8H	21.6	22.5	22.1	23.0	23.5	25.1	26.0	25.6	26.5	27.0
	12H	21.7	22.5	22.2	23.0	23.5	25.7	26.4	26.2	27.0	27.5
8H	4H	21.8	22.6	22.3	23.1	23.6	23.9	24.8	24.4	25.3	25.8
	6H	22.3	23.0	22.8	23.5	24.1	25.1	25.8	25.6	26.3	26.9
	8H	22.5	23.1	23.0	23.7	24.2	25.7	26.3	26.2	26.9	27.4
	12H	22.6	23.2	23.1	23.7	24.3	26.3	26.9	26.9	27.4	28.0
12H	4H	21.9	22.7	22.4	23.2	23.7	23.9	24.7	24.5	25.3	25.8
	6H	22.5	23.2	23.1	23.7	24.3	25.2	25.8	25.7	26.3	26.9
	8H	22.8	23.3	23.3	23.9	24.5	25.8	26.4	26.3	26.9	27.5

Maximum UGR = 28.0

POLAR GRAPH



Maximum Candela = 3099.149 Located At Horizontal Angle = 90, Vertical Angle = 3.5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (3.5) (Through Max. Cd.)