



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 2 SEL35 UV FR 940 @500MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-003(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/6/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL N G2 2 SEL35 UV FR 940

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] One LS3872A 64 LED board, 4000K

[BALLAST] One KTLD-35-UV-PS650-54-VDIM-LM1 LED driver set at 500mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	3788
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	153
Total Luminaire Watts	24.8
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	1.99 ft
Luminous Width (90-270)	0.21 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	27347	24988	24665
55	23420	21887	21850
65	18565	18283	18532
75	13327	14659	14817
85	7363	11889	11676

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 2 SEL35 UV FR 940 @500MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	463.20	N.A.	12.20
0-30	985.48	N.A.	26.00
0-40	1612.86	N.A.	42.60
0-60	2818.94	N.A.	74.40
0-80	3514.57	N.A.	92.80
0-90	3654.88	N.A.	96.50
10-90	3535.3	N.A.	93.30
20-40	1149.66	N.A.	30.30
20-50	1790.78	N.A.	47.30
40-70	1632.08	N.A.	43.10
60-80	695.63	N.A.	18.40
70-80	269.62	N.A.	7.10
80-90	140.31	N.A.	3.70
90-110	97.04	N.A.	2.60
90-120	113.80	N.A.	3.00
90-130	123.01	N.A.	3.20
90-150	131.26	N.A.	3.50
90-180	133.57	N.A.	3.50
110-180	36.53	N.A.	1.00
0-180	3788.45	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	119.58
10-20	343.62
20-30	522.28
30-40	627.38
40-50	641.12
50-60	564.96
60-70	426.00
70-80	269.62
80-90	140.31
90-100	65.20
100-110	31.84
110-120	16.76
120-130	9.21
130-140	5.26
140-150	2.99
150-160	1.65
160-170	0.60
170-180	0.06

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 2 SEL35 UV FR 940 @500MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	96
1	107	102	98	93	104	100	95	92	95	91	88	90	87	85	86	84	82	79
2	97	89	82	76	94	87	80	75	82	77	72	79	74	70	75	71	68	66
3	89	78	70	63	86	76	68	62	73	66	61	69	64	59	66	62	58	55
4	81	69	60	53	79	67	59	53	65	57	52	62	56	51	59	54	50	47
5	75	62	53	46	72	60	52	45	58	50	45	55	49	44	53	48	43	41
6	69	56	47	40	67	54	46	40	52	45	39	50	44	38	48	42	38	36
7	64	50	42	35	62	49	41	35	47	40	35	46	39	34	44	38	34	32
8	60	46	37	32	58	45	37	31	43	36	31	42	35	31	41	35	30	28
9	56	42	34	28	54	41	34	28	40	33	28	39	32	28	37	32	27	25
10	52	39	31	26	51	38	31	26	37	30	25	36	29	25	35	29	25	23

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 2 SEL35 UV FR 940 @500MA.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise


X=2H	Y=2H	21.2	22.7	21.6	23.1	23.6	23.3	24.9	23.7	25.3	25.7
	3H	22.4	23.8	22.8	24.2	24.7	25.3	26.7	25.8	27.1	27.6
	4H	22.7	24.1	23.2	24.5	25.0	26.2	27.5	26.6	27.9	28.4
	6H	22.9	24.2	23.4	24.6	25.1	27.0	28.2	27.5	28.7	29.2
	8H	23.0	24.2	23.5	24.6	25.1	27.4	28.6	27.9	29.0	29.5
	12H	23.0	24.1	23.5	24.6	25.1	27.8	28.9	28.3	29.4	29.9

UGR Viewed Endwise

4H	2H	22.0	23.4	22.5	23.8	24.3	23.7	25.1	24.2	25.5	26.0
	3H	23.5	24.6	24.0	25.1	25.6	25.9	27.1	26.4	27.5	28.0
	4H	24.0	25.0	24.5	25.5	26.0	27.0	28.0	27.5	28.5	29.0
	6H	24.3	25.2	24.8	25.7	26.2	27.9	28.8	28.5	29.3	29.9
	8H	24.3	25.2	24.9	25.7	26.2	28.4	29.2	28.9	29.8	30.3
	12H	24.4	25.1	24.9	25.7	26.2	28.9	29.7	29.4	30.2	30.8
8H	4H	24.5	25.4	25.0	25.9	26.4	27.1	28.0	27.7	28.5	29.1
	6H	25.0	25.7	25.5	26.3	26.8	28.3	29.0	28.8	29.5	30.1
	8H	25.1	25.8	25.7	26.3	26.9	28.9	29.5	29.4	30.1	30.6
	12H	25.2	25.8	25.8	26.3	27.0	29.5	30.1	30.1	30.6	31.3
12H	4H	24.6	25.4	25.2	25.9	26.5	27.1	27.9	27.7	28.4	29.0
	6H	25.2	25.8	25.8	26.4	27.0	28.3	28.9	28.9	29.5	30.1
	8H	25.4	26.0	26.0	26.5	27.2	29.0	29.5	29.5	30.1	30.7

Maximum UGR = 31.3

POLAR GRAPH



Maximum Candela = 1267.32 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)