



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 2 SEL35 UV FR 940 @600MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-003(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/6/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL N G2 2 SEL35 UV FR 940

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] One LS3872A 64 LED board, 4000K

[BALLAST] One KTLD-35-UV-PS650-54-VDIM-LM1 LED driver set at 600mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4481
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	149
Total Luminaire Watts	30.1
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	1.99 ft
Luminous Width (90-270)	0.21 ft
Luminous Height	0.06 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	32342	29553	29170
55	27698	25886	25842
65	21957	21623	21918
75	15762	17337	17523
85	8708	14061	13809

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL N G2 2 SEL35 UV FR 940 @600MA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	547.82	N.A.	12.20
0-30	1165.51	N.A.	26.00
0-40	1907.5	N.A.	42.60
0-60	3333.91	N.A.	74.40
0-80	4156.62	N.A.	92.80
0-90	4322.56	N.A.	96.50
10-90	4181.14	N.A.	93.30
20-40	1359.68	N.A.	30.30
20-50	2117.93	N.A.	47.30
40-70	1930.24	N.A.	43.10
60-80	822.71	N.A.	18.40
70-80	318.88	N.A.	7.10
80-90	165.95	N.A.	3.70
90-110	114.77	N.A.	2.60
90-120	134.59	N.A.	3.00
90-130	145.48	N.A.	3.20
90-150	155.24	N.A.	3.50
90-180	157.97	N.A.	3.50
110-180	43.21	N.A.	1.00
0-180	4480.54	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	141.42
10-20	406.40
20-30	617.69
30-40	741.99
40-50	758.25
50-60	668.16
60-70	503.83
70-80	318.88
80-90	165.95
90-100	77.11
100-110	37.66
110-120	19.82
120-130	10.89
130-140	6.22
140-150	3.54
150-160	1.96
160-170	0.71
170-180	0.08

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL N G2 2 SEL35 UV FR 940 @600MA.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	96
1	107	102	98	93	104	99	95	92	95	91	88	90	87	85	86	84	82	79
2	97	89	82	76	94	87	80	75	82	77	72	79	74	70	75	71	68	66
3	89	78	70	63	86	76	68	62	73	66	61	69	64	59	66	62	58	55
4	81	69	60	53	79	67	59	53	64	57	52	62	56	51	59	54	49	47
5	75	62	53	46	72	60	52	45	58	50	45	55	49	44	53	48	43	41
6	69	56	47	40	67	54	46	40	52	45	39	50	44	38	48	42	38	36
7	64	50	42	35	62	49	41	35	47	40	35	46	39	34	44	38	34	32
8	60	46	37	32	58	45	37	31	43	36	31	42	35	31	40	35	30	28
9	56	42	34	28	54	41	34	28	40	33	28	39	32	28	37	32	27	25
10	52	39	31	26	51	38	31	26	37	30	25	36	29	25	35	29	25	23

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 2 SEL35 UV FR 940 @600MA.IES

## UGR TABLE - CORRECTED

### Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

### Room Size UGR Viewed Crosswise


X=2H	Y=2H	21.8	23.3	22.2	23.7	24.2	23.9	25.5	24.3	25.9	26.3
	3H	23.0	24.4	23.4	24.8	25.3	25.9	27.3	26.4	27.7	28.2
	4H	23.3	24.7	23.8	25.1	25.6	26.8	28.1	27.2	28.5	29.0
	6H	23.5	24.8	24.0	25.2	25.7	27.6	28.8	28.1	29.3	29.8
	8H	23.6	24.8	24.1	25.2	25.7	28.0	29.2	28.5	29.6	30.1
	12H	23.6	24.7	24.1	25.2	25.7	28.4	29.5	28.9	30.0	30.5

### UGR Viewed Endwise

4H	2H	22.6	24.0	23.1	24.4	24.9	24.3	25.7	24.8	26.1	26.6
	3H	24.1	25.2	24.6	25.7	26.2	26.5	27.7	27.0	28.1	28.6
	4H	24.6	25.6	25.1	26.1	26.6	27.6	28.6	28.1	29.1	29.6
	6H	24.9	25.8	25.4	26.3	26.8	28.5	29.4	29.1	29.9	30.5
	8H	24.9	25.8	25.5	26.3	26.8	29.0	29.8	29.5	30.4	30.9
	12H	25.0	25.7	25.5	26.3	26.8	29.5	30.3	30.0	30.8	31.4
8H	4H	25.1	26.0	25.6	26.5	27.0	27.7	28.6	28.3	29.1	29.7
	6H	25.6	26.3	26.1	26.9	27.4	28.9	29.6	29.4	30.1	30.7
	8H	25.7	26.4	26.3	26.9	27.5	29.5	30.1	30.0	30.7	31.2
	12H	25.8	26.4	26.4	26.9	27.6	30.1	30.7	30.7	31.2	31.9
12H	4H	25.2	26.0	25.8	26.5	27.1	27.7	28.5	28.3	29.0	29.6
	6H	25.8	26.4	26.4	27.0	27.6	28.9	29.5	29.5	30.1	30.7
	8H	26.0	26.6	26.6	27.1	27.8	29.6	30.1	30.1	30.7	31.3

Maximum UGR = 31.9

POLAR GRAPH



Maximum Candela = 1498.837 Located At Horizontal Angle = 90, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)