



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 4 SEL45 UV FR 930 @800MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-006(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/6/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL N G2 4 SEL45 UV FR 930

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Two LS3872A 48 LED boards, 3000K

[BALLAST] One KTLD-45-UV-PS850-54-VDIM-LM1 LED driver set at 800mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	5885
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	146
Total Luminaire Watts	40.2
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	3.84 ft
Luminous Width (90-270)	0.21 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	22815	20369	19841
55	19808	17971	17573
65	15867	15064	14745
75	11513	12015	11553
85	6627	9694	8758

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 4 SEL45 UV FR 930 @800MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	721.56	N.A.	12.30
0-30	1534.31	N.A.	26.10
0-40	2512.04	N.A.	42.70
0-60	4402.76	N.A.	74.80
0-80	5485.36	N.A.	93.20
0-90	5696.38	N.A.	96.80
10-90	5509.99	N.A.	93.60
20-40	1790.48	N.A.	30.40
20-50	2793.93	N.A.	47.50
40-70	2557.55	N.A.	43.50
60-80	1082.61	N.A.	18.40
70-80	415.77	N.A.	7.10
80-90	211.02	N.A.	3.60
90-110	141.76	N.A.	2.40
90-120	165.47	N.A.	2.80
90-130	178.02	N.A.	3.00
90-150	187.43	N.A.	3.20
90-180	189.08	N.A.	3.20
110-180	47.32	N.A.	0.80
0-180	5885.46	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	186.39
10-20	535.17
20-30	812.75
30-40	977.74
40-50	1003.45
50-60	887.26
60-70	666.84
70-80	415.77
80-90	211.02
90-100	95.68
100-110	46.08
110-120	23.72
120-130	12.54
130-140	6.42
140-150	2.99
150-160	1.28
160-170	0.37
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 4 SEL45 UV FR 930 @800MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	97
1	107	102	98	94	104	100	96	92	95	91	88	90	88	85	86	84	82	80
2	97	89	82	76	95	87	80	75	83	77	73	79	74	70	75	72	68	66
3	89	78	70	63	86	76	69	62	73	66	61	70	64	59	67	62	58	56
4	81	69	60	53	79	68	59	53	65	57	52	62	56	51	59	54	50	47
5	75	62	53	46	72	60	52	46	58	50	45	56	49	44	53	48	43	41
6	69	56	47	40	67	54	46	40	52	45	39	50	44	39	48	43	38	36
7	64	50	42	35	62	49	41	35	48	40	35	46	39	34	44	38	34	32
8	60	46	37	32	58	45	37	31	44	36	31	42	35	31	41	35	30	28
9	56	42	34	28	54	41	34	28	40	33	28	39	32	28	38	32	27	25
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 4 SEL45 UV FR 930 @800MA.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise


X=2H	Y=2H	20.7	22.3	21.1	22.7	23.1	22.7	24.3	23.1	24.7	25.1
	3H	21.9	23.4	22.4	23.7	24.2	24.7	26.1	25.1	26.5	27.0
	4H	22.3	23.6	22.7	24.0	24.5	25.6	26.9	26.0	27.3	27.8
	6H	22.5	23.7	22.9	24.2	24.6	26.3	27.6	26.8	28.0	28.5
	8H	22.5	23.7	23.0	24.2	24.6	26.7	27.9	27.2	28.4	28.8
	12H	22.5	23.7	23.0	24.1	24.6	27.1	28.3	27.6	28.7	29.2

UGR Viewed Endwise

4H	2H	21.6	22.9	22.0	23.3	23.8	23.2	24.5	23.6	24.9	25.4
	3H	23.0	24.1	23.4	24.6	25.1	25.3	26.5	25.8	26.9	27.4
	4H	23.5	24.5	23.9	25.0	25.5	26.3	27.4	26.8	27.8	28.3
	6H	23.8	24.7	24.3	25.2	25.7	27.3	28.2	27.8	28.7	29.2
	8H	23.8	24.7	24.3	25.2	25.7	27.7	28.6	28.2	29.1	29.6
	12H	23.9	24.6	24.4	25.2	25.7	28.2	29.0	28.7	29.5	30.1
8H	4H	24.0	24.9	24.5	25.4	25.9	26.5	27.4	27.0	27.9	28.4
	6H	24.5	25.2	25.0	25.7	26.3	27.6	28.3	28.1	28.9	29.4
	8H	24.6	25.3	25.1	25.8	26.4	28.2	28.8	28.7	29.4	29.9
	12H	24.7	25.3	25.2	25.8	26.4	28.8	29.4	29.3	29.9	30.5
12H	4H	24.1	24.9	24.6	25.4	26.0	26.5	27.3	27.0	27.8	28.4
	6H	24.7	25.3	25.2	25.8	26.4	27.6	28.3	28.2	28.8	29.4
	8H	24.9	25.5	25.4	26.0	26.6	28.3	28.8	28.8	29.4	30.0

Maximum UGR = 30.5

POLAR GRAPH



Maximum Candela = 1979.42 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)