



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 4 SEL35 UV FR 935 @500MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-006(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/6/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL N G2 4 SEL35 UV FR 935

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Two LS3872A 48 LED boards, 3500K

[BALLAST] One KTLD-35-UV-PS650-54-VDIM-LM1 LED driver set at 500mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	3750
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	155
Total Luminaire Watts	24.2
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	3.84 ft
Luminous Width (90-270)	0.21 ft
Luminous Height	0.06 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	14538	12979	12643
55	12622	11452	11198
65	10111	9599	9396
75	7337	7656	7362
85	4223	6177	5581

**IES INDOOR REPORT****PHOTOMETRIC FILENAME : ECL N G2 4 SEL35 UV FR 935 @500MA.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	459.79	N.A.	12.30
0-30	977.69	N.A.	26.10
0-40	1600.72	N.A.	42.70
0-60	2805.52	N.A.	74.80
0-80	3495.37	N.A.	93.20
0-90	3629.84	N.A.	96.80
10-90	3511.07	N.A.	93.60
20-40	1140.93	N.A.	30.40
20-50	1780.34	N.A.	47.50
40-70	1629.72	N.A.	43.50
60-80	689.86	N.A.	18.40
70-80	264.94	N.A.	7.10
80-90	134.46	N.A.	3.60
90-110	90.33	N.A.	2.40
90-120	105.44	N.A.	2.80
90-130	113.44	N.A.	3.00
90-150	119.43	N.A.	3.20
90-180	120.48	N.A.	3.20
110-180	30.15	N.A.	0.80
0-180	3750.32	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	118.77
10-20	341.02
20-30	517.90
30-40	623.03
40-50	639.42
50-60	565.38
60-70	424.92
70-80	264.94
80-90	134.46
90-100	60.97
100-110	29.36
110-120	15.11
120-130	7.99
130-140	4.09
140-150	1.91
150-160	0.82
160-170	0.23
170-180	0.00

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 4 SEL35 UV FR 935 @500MA.IES

## COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	97
1	107	102	98	94	104	100	96	92	95	91	88	90	88	85	86	84	82	80
2	97	89	82	76	95	87	80	75	83	77	73	79	74	70	75	72	68	66
3	89	78	70	63	86	76	69	62	73	66	61	70	64	59	67	62	58	56
4	81	69	60	53	79	68	59	53	65	57	52	62	56	51	59	54	50	47
5	75	62	53	46	72	60	52	46	58	50	45	56	49	44	53	48	43	41
6	69	56	47	40	67	54	46	40	52	45	39	50	44	39	48	43	38	36
7	64	50	42	35	62	49	41	35	48	40	35	46	39	34	44	38	34	32
8	60	46	37	32	58	45	37	31	44	36	31	42	35	31	41	35	30	28
9	56	42	34	28	54	41	34	28	40	33	28	39	32	28	38	32	27	25
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL N G2 4 SEL35 UV FR 935 @500MA.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size											
		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	19.1	20.7	19.5	21.1	21.5	21.1	22.7	21.5	23.1	23.5
	3H	20.3	21.8	20.8	22.1	22.6	23.1	24.5	23.5	24.9	25.4
	4H	20.7	22.0	21.1	22.4	22.9	24.0	25.3	24.4	25.7	26.2
	6H	20.9	22.1	21.3	22.6	23.0	24.7	26.0	25.2	26.4	26.9
	8H	20.9	22.1	21.4	22.6	23.0	25.1	26.3	25.6	26.8	27.2
	12H	20.9	22.1	21.4	22.5	23.0	25.5	26.7	26.0	27.1	27.6
4H	2H	20.0	21.3	20.4	21.7	22.2	21.6	22.9	22.0	23.3	23.8
	3H	21.4	22.5	21.8	23.0	23.5	23.7	24.9	24.2	25.3	25.8
	4H	21.9	22.9	22.3	23.4	23.9	24.7	25.8	25.2	26.2	26.7
	6H	22.2	23.1	22.7	23.6	24.1	25.7	26.6	26.2	27.1	27.6
	8H	22.2	23.1	22.7	23.6	24.1	26.1	27.0	26.6	27.5	28.0
	12H	22.3	23.0	22.8	23.6	24.1	26.6	27.4	27.1	27.9	28.5
8H	4H	22.4	23.3	22.9	23.8	24.3	24.9	25.8	25.4	26.3	26.8
	6H	22.9	23.6	23.4	24.1	24.7	26.0	26.7	26.5	27.3	27.8
	8H	23.0	23.7	23.5	24.2	24.8	26.6	27.2	27.1	27.8	28.3
	12H	23.1	23.7	23.6	24.2	24.8	27.2	27.8	27.7	28.3	28.9
12H	4H	22.5	23.3	23.0	23.8	24.4	24.9	25.7	25.4	26.2	26.8
	6H	23.1	23.7	23.6	24.2	24.8	26.0	26.7	26.6	27.2	27.8
	8H	23.3	23.9	23.8	24.4	25.0	26.7	27.2	27.2	27.8	28.4

Maximum UGR = 28.9

POLAR GRAPH



Maximum Candela = 1261.322 Located At Horizontal Angle = 90, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)