



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 4 SEL45 UV FR 940 @800MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-006(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/6/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL N G2 4 SEL45 UV FR 940

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Two LS3872A 48 LED boards, 4000K

[BALLAST] One KTLD-45-UV-PS850-54-VDIM-LM1 LED driver set at 800mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	6051
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	151
Total Luminaire Watts	40.2
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	3.84 ft
Luminous Width (90-270)	0.21 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	23456	20941	20398
55	20364	18476	18066
65	16313	15486	15158
75	11836	12353	11877
85	6813	9966	9004

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 4 SEL45 UV FR 940 @800MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	741.81	N.A.	12.30
0-30	1577.37	N.A.	26.10
0-40	2582.55	N.A.	42.70
0-60	4526.32	N.A.	74.80
0-80	5639.32	N.A.	93.20
0-90	5856.26	N.A.	96.80
10-90	5664.64	N.A.	93.60
20-40	1840.73	N.A.	30.40
20-50	2872.35	N.A.	47.50
40-70	2629.33	N.A.	43.50
60-80	1112.99	N.A.	18.40
70-80	427.44	N.A.	7.10
80-90	216.94	N.A.	3.60
90-110	145.73	N.A.	2.40
90-120	170.12	N.A.	2.80
90-130	183.02	N.A.	3.00
90-150	192.69	N.A.	3.20
90-180	194.38	N.A.	3.20
110-180	48.65	N.A.	0.80
0-180	6050.64	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	191.62
10-20	550.19
20-30	835.56
30-40	1005.18
40-50	1031.61
50-60	912.16
60-70	685.55
70-80	427.44
80-90	216.94
90-100	98.36
100-110	47.37
110-120	24.39
120-130	12.90
130-140	6.60
140-150	3.07
150-160	1.32
160-170	0.38
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 4 SEL45 UV FR 940 @800MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	97
1	107	102	98	94	104	100	96	92	95	91	88	90	88	85	86	84	82	80
2	97	89	82	76	94	87	80	75	83	77	73	79	74	70	75	72	68	66
3	89	78	70	63	86	76	69	62	73	66	61	70	64	59	67	62	58	56
4	81	69	60	53	79	68	59	53	65	57	52	62	56	51	59	54	50	47
5	75	62	53	46	72	60	52	46	58	50	45	56	49	44	53	48	43	41
6	69	56	47	40	67	54	46	40	52	45	39	50	44	39	48	43	38	36
7	64	50	42	35	62	49	41	35	48	40	35	46	39	34	44	38	34	32
8	60	46	37	32	58	45	37	31	44	36	31	42	35	31	41	35	30	28
9	56	42	34	28	54	41	34	28	40	33	28	39	32	28	38	32	27	25
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 4 SEL45 UV FR 940 @800MA.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise


X=2H	Y=2H	20.8	22.4	21.2	22.8	23.2	22.8	24.4	23.2	24.8	25.2
	3H	22.0	23.5	22.5	23.8	24.3	24.8	26.2	25.2	26.6	27.1
	4H	22.4	23.7	22.8	24.1	24.6	25.7	27.0	26.1	27.4	27.9
	6H	22.6	23.8	23.0	24.3	24.7	26.4	27.7	26.9	28.1	28.6
	8H	22.6	23.8	23.1	24.3	24.7	26.8	28.0	27.3	28.5	28.9
	12H	22.6	23.8	23.1	24.2	24.7	27.2	28.3	27.7	28.8	29.3

UGR Viewed Endwise

4H	2H	21.7	23.0	22.1	23.4	23.9	23.3	24.6	23.7	25.0	25.5
	3H	23.1	24.2	23.5	24.7	25.2	25.4	26.6	25.9	27.0	27.5
	4H	23.6	24.6	24.0	25.1	25.6	26.4	27.5	26.9	27.9	28.4
	6H	23.9	24.8	24.4	25.3	25.8	27.4	28.3	27.9	28.8	29.3
	8H	23.9	24.8	24.4	25.3	25.8	27.8	28.7	28.3	29.2	29.7
	12H	24.0	24.7	24.5	25.3	25.8	28.3	29.1	28.8	29.6	30.2
8H	4H	24.1	25.0	24.6	25.5	26.0	26.6	27.5	27.1	28.0	28.5
	6H	24.6	25.3	25.1	25.8	26.4	27.7	28.4	28.2	29.0	29.5
	8H	24.7	25.4	25.2	25.9	26.5	28.3	28.9	28.8	29.5	30.0
	12H	24.8	25.4	25.3	25.9	26.5	28.9	29.5	29.4	30.0	30.6
12H	4H	24.2	25.0	24.7	25.5	26.1	26.6	27.4	27.1	27.9	28.5
	6H	24.8	25.4	25.3	25.9	26.5	27.7	28.4	28.3	28.9	29.5
	8H	25.0	25.6	25.5	26.1	26.7	28.4	28.9	28.9	29.5	30.1

Maximum UGR = 30.6

POLAR GRAPH



Maximum Candela = 2034.975 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)