



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 6 SEL15 UV FR 940 @230MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-006(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/6/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL N G2 6 SEL15 UV FR 940

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Three LS3872A 28 LED boards, 4000K

[BALLAST] One KTLD-15-UV-PS300-54-VDIM-LP1 LED driver set at 230mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1537
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	151
Total Luminaire Watts	10.2
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	5.84 ft
Luminous Width (90-270)	0.21 ft
Luminous Height	0.06 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	3941	3510	3408
55	3429	3100	3018
65	2758	2602	2533
75	2017	2081	1984
85	1203	1686	1504

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL N G2 6 SEL15 UV FR 940 @230MA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	188.43	N.A.	12.30
0-30	400.67	N.A.	26.10
0-40	655.99	N.A.	42.70
0-60	1149.73	N.A.	74.80
0-80	1432.44	N.A.	93.20
0-90	1487.54	N.A.	96.80
10-90	1438.87	N.A.	93.60
20-40	467.56	N.A.	30.40
20-50	729.60	N.A.	47.50
40-70	667.87	N.A.	43.50
60-80	282.71	N.A.	18.40
70-80	108.57	N.A.	7.10
80-90	55.10	N.A.	3.60
90-110	37.02	N.A.	2.40
90-120	43.21	N.A.	2.80
90-130	46.49	N.A.	3.00
90-150	48.94	N.A.	3.20
90-180	49.38	N.A.	3.20
110-180	12.36	N.A.	0.80
0-180	1536.92	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	48.67
10-20	139.75
20-30	212.24
30-40	255.32
40-50	262.04
50-60	231.70
60-70	174.14
70-80	108.57
80-90	55.10
90-100	24.98
100-110	12.03
110-120	6.19
120-130	3.28
130-140	1.68
140-150	0.78
150-160	0.33
160-170	0.10
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : ECL N G2 6 SEL15 UV FR 940 @230MA.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	97
1	107	102	98	94	104	100	96	92	95	91	88	90	88	85	86	84	82	80
2	97	89	82	76	94	87	80	75	83	77	73	79	74	70	75	72	68	66
3	89	78	70	63	86	76	69	62	73	66	61	70	64	59	67	62	58	56
4	81	69	60	53	79	68	59	53	65	57	52	62	56	51	59	54	50	47
5	75	62	53	46	72	60	52	46	58	50	45	56	49	44	53	48	43	41
6	69	56	47	40	67	54	46	40	52	45	39	50	44	39	48	43	38	36
7	64	50	42	35	62	49	41	35	48	40	35	46	39	34	44	38	34	32
8	60	46	37	32	58	45	37	31	44	36	31	42	35	31	41	35	30	28
9	56	42	34	28	54	41	34	28	40	33	28	39	32	28	38	32	27	25
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 6 SEL15 UV FR 940 @230MA.IES

## UGR TABLE - CORRECTED

### Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

### Room Size UGR Viewed Crosswise


X=2H	Y=2H	14.6	16.1	15.0	16.5	16.9	16.6	18.2	17.0	18.6	19.0
	3H	15.8	17.2	16.2	17.6	18.0	18.6	20.0	19.0	20.4	20.8
	4H	16.1	17.5	16.6	17.9	18.3	19.4	20.8	19.9	21.2	21.6
	6H	16.3	17.6	16.8	18.0	18.5	20.2	21.5	20.7	21.9	22.4
	8H	16.3	17.6	16.8	18.0	18.5	20.6	21.8	21.1	22.3	22.7
	12H	16.4	17.5	16.8	18.0	18.5	21.0	22.2	21.5	22.6	23.1

### UGR Viewed Endwise

4H	2H	15.4	16.8	15.9	17.2	17.6	17.0	18.4	17.5	18.8	19.2
	3H	16.8	18.0	17.3	18.4	18.9	19.2	20.4	19.7	20.8	21.3
	4H	17.3	18.4	17.8	18.8	19.3	20.2	21.2	20.7	21.7	22.2
	6H	17.6	18.5	18.1	19.0	19.6	21.2	22.1	21.7	22.6	23.1
	8H	17.7	18.5	18.2	19.0	19.6	21.6	22.5	22.1	23.0	23.5
	12H	17.7	18.5	18.2	19.0	19.6	22.1	22.9	22.6	23.4	24.0
8H	4H	17.9	18.7	18.4	19.2	19.8	20.4	21.3	20.9	21.7	22.3
	6H	18.3	19.0	18.9	19.6	20.1	21.5	22.2	22.0	22.8	23.3
	8H	18.5	19.1	19.0	19.7	20.2	22.1	22.7	22.6	23.3	23.8
	12H	18.6	19.1	19.1	19.7	20.3	22.7	23.3	23.3	23.8	24.5
12H	4H	18.0	18.8	18.5	19.3	19.8	20.4	21.2	20.9	21.7	22.2
	6H	18.5	19.2	19.1	19.7	20.3	21.5	22.2	22.1	22.7	23.3
	8H	18.7	19.3	19.3	19.9	20.5	22.2	22.7	22.7	23.3	23.9

Maximum UGR = 24.5

POLAR GRAPH



Maximum Candela = 516.902 Located At Horizontal Angle = 90, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)