



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 8 SEL100 UV FR 940 @1600MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-006(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/6/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL N G2 8 SEL100 UV FR 940

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Four LS3872A 48 LED boards, 4000K

[BALLAST] One KTLD-100-UV-PS1800-54-VDIM-LM2 LED driver set at 1600mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	12103
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	152
Total Luminaire Watts	79.5
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	7.67 ft
Luminous Width (90-270)	0.21 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	23714	21100	20457
55	20658	18645	18117
65	16641	15661	15202
75	12222	12535	11911
85	7416	10182	9030

IES INDOOR REPORT**PHOTOMETRIC FILENAME : ECL N G2 8 SEL100 UV FR 940 @1600MA.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	1483.81	N.A.	12.30
0-30	3155.12	N.A.	26.10
0-40	5165.71	N.A.	42.70
0-60	9053.73	N.A.	74.80
0-80	11279.98	N.A.	93.20
0-90	11713.91	N.A.	96.80
10-90	11330.63	N.A.	93.60
20-40	3681.91	N.A.	30.40
20-50	5745.38	N.A.	47.50
40-70	5259.29	N.A.	43.50
60-80	2226.25	N.A.	18.40
70-80	854.98	N.A.	7.10
80-90	433.93	N.A.	3.60
90-110	291.50	N.A.	2.40
90-120	340.28	N.A.	2.80
90-130	366.07	N.A.	3.00
90-150	385.42	N.A.	3.20
90-180	388.81	N.A.	3.20
110-180	97.31	N.A.	0.80
0-180	12102.73	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	383.28
10-20	1100.52
20-30	1671.32
30-40	2010.59
40-50	2063.47
50-60	1824.55
60-70	1371.27
70-80	854.98
80-90	433.93
90-100	196.75
100-110	94.76
110-120	48.78
120-130	25.80
130-140	13.20
140-150	6.15
150-160	2.63
160-170	0.76
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 8 SEL100 UV FR 940 @1600MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	97
1	107	102	98	94	104	100	96	92	95	91	88	90	88	85	86	84	82	80
2	97	89	82	76	94	87	80	75	83	77	73	79	74	70	75	72	68	66
3	89	78	70	63	86	76	69	62	73	66	61	70	64	59	67	62	58	56
4	81	69	60	53	79	68	59	53	65	57	52	62	56	51	59	54	50	47
5	75	62	53	46	72	60	52	46	58	50	45	56	49	44	53	48	43	41
6	69	56	47	40	67	54	46	40	52	45	39	50	44	39	48	43	38	36
7	64	50	42	35	62	49	41	35	48	40	35	46	39	34	44	38	34	32
8	60	46	37	32	58	45	37	31	44	36	31	42	35	31	41	35	30	28
9	56	42	34	28	54	41	34	28	40	33	28	39	32	28	38	32	27	25
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 8 SEL100 UV FR 940 @1600MA.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise


X=2H	Y=2H	20.8	22.4	21.2	22.8	23.2	22.9	24.5	23.3	24.8	25.2
	3H	22.0	23.5	22.5	23.9	24.3	24.9	26.3	25.3	26.7	27.1
	4H	22.4	23.7	22.8	24.1	24.6	25.7	27.1	26.2	27.5	27.9
	6H	22.6	23.8	23.0	24.3	24.7	26.5	27.8	27.0	28.2	28.7
	8H	22.6	23.8	23.1	24.3	24.7	26.9	28.1	27.4	28.5	29.0
	12H	22.6	23.8	23.1	24.2	24.7	27.3	28.4	27.8	28.9	29.4

UGR Viewed Endwise

4H	2H	21.7	23.0	22.1	23.4	23.9	23.3	24.6	23.7	25.1	25.5
	3H	23.1	24.3	23.6	24.7	25.2	25.5	26.6	25.9	27.1	27.6
	4H	23.6	24.6	24.1	25.1	25.6	26.5	27.5	27.0	28.0	28.5
	6H	23.9	24.8	24.4	25.3	25.8	27.4	28.4	27.9	28.9	29.4
	8H	23.9	24.8	24.4	25.3	25.8	27.9	28.8	28.4	29.3	29.8
	12H	24.0	24.8	24.5	25.3	25.8	28.4	29.2	28.9	29.7	30.3
8H	4H	24.1	25.0	24.6	25.5	26.0	26.7	27.5	27.2	28.0	28.6
	6H	24.6	25.3	25.1	25.9	26.4	27.8	28.5	28.3	29.0	29.6
	8H	24.7	25.4	25.3	25.9	26.5	28.3	29.0	28.9	29.6	30.1
	12H	24.8	25.4	25.4	25.9	26.6	29.0	29.6	29.5	30.1	30.7
12H	4H	24.2	25.0	24.8	25.6	26.1	26.7	27.4	27.2	28.0	28.5
	6H	24.8	25.4	25.3	26.0	26.6	27.8	28.5	28.4	29.0	29.6
	8H	25.0	25.6	25.6	26.1	26.8	28.4	29.0	29.0	29.6	30.2

Maximum UGR = 30.7

POLAR GRAPH



Maximum Candela = 4070.437 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)