



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 8 SEL35 UV FR 935 @550MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-006(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/6/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL N G2 8 SEL35 UV FR 935

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Four LS3872A 48 LED boards, 3500K

[BALLAST] One KTLD-35-UV-PS650-54-VDIM-LM1 LED driver set at 550mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4109
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	157
Total Luminaire Watts	26.1
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	7.67 ft
Luminous Width (90-270)	0.21 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	8050	7163	6945
55	7013	6330	6151
65	5649	5317	5161
75	4149	4255	4044
85	2517	3457	3065

IES INDOOR REPORT**PHOTOMETRIC FILENAME : ECL N G2 8 SEL35 UV FR 935 @550MA.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	503.73	N.A.	12.30
0-30	1071.12	N.A.	26.10
0-40	1753.68	N.A.	42.70
0-60	3073.61	N.A.	74.80
0-80	3829.39	N.A.	93.20
0-90	3976.7	N.A.	96.80
10-90	3846.58	N.A.	93.60
20-40	1249.95	N.A.	30.40
20-50	1950.47	N.A.	47.50
40-70	1785.45	N.A.	43.50
60-80	755.78	N.A.	18.40
70-80	290.25	N.A.	7.10
80-90	147.31	N.A.	3.60
90-110	98.96	N.A.	2.40
90-120	115.52	N.A.	2.80
90-130	124.28	N.A.	3.00
90-150	130.84	N.A.	3.20
90-180	132.00	N.A.	3.20
110-180	33.04	N.A.	0.80
0-180	4108.7	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	130.12
10-20	373.61
20-30	567.39
30-40	682.57
40-50	700.52
50-60	619.41
60-70	465.53
70-80	290.25
80-90	147.31
90-100	66.79
100-110	32.17
110-120	16.56
120-130	8.76
130-140	4.48
140-150	2.09
150-160	0.89
160-170	0.26
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 8 SEL35 UV FR 935 @550MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	97
1	107	102	98	94	104	100	96	92	95	91	88	90	88	85	86	84	82	80
2	97	89	82	76	94	87	80	75	83	77	73	79	74	70	75	72	68	66
3	89	78	70	63	86	76	69	62	73	66	61	70	64	59	67	62	58	56
4	81	69	60	53	79	68	59	53	65	57	52	62	56	51	59	54	50	47
5	75	62	53	46	72	60	52	46	58	50	45	56	49	44	53	48	43	41
6	69	56	47	40	67	54	46	40	52	45	39	50	44	39	48	43	38	36
7	64	50	42	35	62	49	41	35	48	40	35	46	39	34	44	38	34	32
8	60	46	37	32	58	45	37	31	44	36	31	42	35	31	41	35	30	28
9	56	42	34	28	54	41	34	28	40	33	28	39	32	28	38	32	27	25
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 8 SEL35 UV FR 935 @550MA.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise

X=2H	Y=2H	17.0	18.6	17.4	19.0	19.4	19.1	20.7	19.5	21.0	21.4
	3H	18.2	19.7	18.7	20.1	20.5	21.1	22.5	21.5	22.9	23.3
	4H	18.6	19.9	19.0	20.3	20.8	21.9	23.3	22.4	23.7	24.1
	6H	18.8	20.0	19.2	20.5	20.9	22.7	24.0	23.2	24.4	24.9
	8H	18.8	20.0	19.3	20.5	20.9	23.1	24.3	23.6	24.7	25.2
	12H	18.8	20.0	19.3	20.4	20.9	23.5	24.6	24.0	25.1	25.6

UGR Viewed Endwise


4H	2H	17.9	19.2	18.3	19.6	20.1	19.5	20.8	19.9	21.3	21.7
	3H	19.3	20.5	19.8	20.9	21.4	21.7	22.8	22.1	23.3	23.8
	4H	19.8	20.8	20.3	21.3	21.8	22.7	23.7	23.2	24.2	24.7
	6H	20.1	21.0	20.6	21.5	22.0	23.6	24.6	24.1	25.1	25.6
	8H	20.1	21.0	20.6	21.5	22.0	24.1	25.0	24.6	25.5	26.0
	12H	20.2	21.0	20.7	21.5	22.0	24.6	25.4	25.1	25.9	26.5

8H	4H	20.3	21.2	20.8	21.7	22.2	22.9	23.7	23.4	24.2	24.8
	6H	20.8	21.5	21.3	22.1	22.6	24.0	24.7	24.5	25.2	25.8
	8H	20.9	21.6	21.5	22.1	22.7	24.5	25.2	25.1	25.8	26.3
	12H	21.0	21.6	21.6	22.1	22.8	25.2	25.8	25.7	26.3	26.9

12H	4H	20.4	21.2	21.0	21.8	22.3	22.9	23.6	23.4	24.2	24.7
	6H	21.0	21.6	21.5	22.2	22.8	24.0	24.7	24.6	25.2	25.8
	8H	21.2	21.8	21.8	22.3	23.0	24.6	25.2	25.2	25.8	26.4

Maximum UGR = 26.9

POLAR GRAPH



Maximum Candela = 1381.854 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)