



IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 8 SEL75 UV FR 935 @1100MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001735-006(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/6/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] ECL N G2 8 SEL75 UV FR 935

[LUMINAIRE] Surface or suspended mounted, formed white painted steel housing/reflector,

[MORE] translucent curved plastic enclosure.

[LAMPCAT] Four LS3872A 48 LED boards, 3500K

[BALLAST] One KTLD-75-UV-PS1400-54-VDIM-LM2 LED driver set at 1100mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	8242
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	154
Total Luminaire Watts	53.5
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.30
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	7.67 ft
Luminous Width (90-270)	0.21 ft
Luminous Height	0.06 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	16150	14370	13932
55	14069	12698	12339
65	11333	10666	10353
75	8323	8537	8112
85	5050	6934	6150

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 8 SEL75 UV FR 935 @1100MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	1010.53	N.A.	12.30
0-30	2148.77	N.A.	26.10
0-40	3518.07	N.A.	42.70
0-60	6165.97	N.A.	74.80
0-80	7682.14	N.A.	93.20
0-90	7977.66	N.A.	96.80
10-90	7716.63	N.A.	93.60
20-40	2507.53	N.A.	30.40
20-50	3912.84	N.A.	47.50
40-70	3581.79	N.A.	43.50
60-80	1516.17	N.A.	18.40
70-80	582.28	N.A.	7.10
80-90	295.52	N.A.	3.60
90-110	198.53	N.A.	2.40
90-120	231.74	N.A.	2.80
90-130	249.31	N.A.	3.00
90-150	262.49	N.A.	3.20
90-180	264.80	N.A.	3.20
110-180	66.27	N.A.	0.80
0-180	8242.46	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	261.03
10-20	749.50
20-30	1138.24
30-40	1369.3
40-50	1405.31
50-60	1242.59
60-70	933.89
70-80	582.28
80-90	295.52
90-100	133.99
100-110	64.53
110-120	33.22
120-130	17.57
130-140	8.99
140-150	4.19
150-160	1.79
160-170	0.52
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : ECL N G2 8 SEL75 UV FR 935 @1100MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	97
1	107	102	98	94	104	100	96	92	95	91	88	90	88	85	86	84	82	80
2	97	89	82	76	94	87	80	75	83	77	73	79	74	70	75	72	68	66
3	89	78	70	63	86	76	69	62	73	66	61	70	64	59	67	62	58	56
4	81	69	60	53	79	68	59	53	65	57	52	62	56	51	59	54	50	47
5	75	62	53	46	72	60	52	46	58	50	45	56	49	44	53	48	43	41
6	69	56	47	40	67	54	46	40	52	45	39	50	44	39	48	43	38	36
7	64	50	42	35	62	49	41	35	48	40	35	46	39	34	44	38	34	32
8	60	46	37	32	58	45	37	31	44	36	31	42	35	31	41	35	30	28
9	56	42	34	28	54	41	34	28	40	33	28	39	32	28	38	32	27	25
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	35	29	25	23

IES INDOOR REPORT

PHOTOMETRIC FILENAME : ECL N G2 8 SEL75 UV FR 935 @1100MA.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise


X=2H	Y=2H	19.4	21.0	19.8	21.4	21.8	21.5	23.1	21.9	23.4	23.8
	3H	20.6	22.1	21.1	22.5	22.9	23.5	24.9	23.9	25.3	25.7
	4H	21.0	22.3	21.4	22.7	23.2	24.3	25.7	24.8	26.1	26.5
	6H	21.2	22.4	21.6	22.9	23.3	25.1	26.4	25.6	26.8	27.3
	8H	21.2	22.4	21.7	22.9	23.3	25.5	26.7	26.0	27.1	27.6
	12H	21.2	22.4	21.7	22.8	23.3	25.9	27.0	26.4	27.5	28.0

UGR Viewed Endwise

4H	2H	20.3	21.6	20.7	22.0	22.5	21.9	23.2	22.3	23.7	24.1
	3H	21.7	22.9	22.2	23.3	23.8	24.1	25.2	24.5	25.7	26.2
	4H	22.2	23.2	22.7	23.7	24.2	25.1	26.1	25.6	26.6	27.1
	6H	22.5	23.4	23.0	23.9	24.4	26.0	27.0	26.5	27.5	28.0
	8H	22.5	23.4	23.0	23.9	24.4	26.5	27.4	27.0	27.9	28.4
	12H	22.6	23.4	23.1	23.9	24.4	27.0	27.8	27.5	28.3	28.9
8H	4H	22.7	23.6	23.2	24.1	24.6	25.3	26.1	25.8	26.6	27.2
	6H	23.2	23.9	23.7	24.5	25.0	26.4	27.1	26.9	27.6	28.2
	8H	23.3	24.0	23.9	24.5	25.1	26.9	27.6	27.5	28.2	28.7
	12H	23.4	24.0	24.0	24.5	25.2	27.6	28.2	28.1	28.7	29.3
12H	4H	22.8	23.6	23.4	24.2	24.7	25.3	26.0	25.8	26.6	27.1
	6H	23.4	24.0	23.9	24.6	25.2	26.4	27.1	27.0	27.6	28.2
	8H	23.6	24.2	24.2	24.7	25.4	27.0	27.6	27.6	28.2	28.8

Maximum UGR = 29.3

POLAR GRAPH



Maximum Candela = 2772.137 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)