



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 2R 22 SEL45 UV FA 940 @700MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-031 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/4/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFL G2 2R 22 SEL45 UV FA 940

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflectors,

[MORE] two frosted linear ribbed plastic enclosures.

[LAMPCAT] Two LS3873A7_4000_90R 4000K 48 LED boards

[BALLAST] One KTLD-45-UV-PS850-54-VDIM-LM1 LED driver set to 700mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	5123
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	147
Total Luminaire Watts	34.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	4884	5224	5563
55	4508	4992	5495
65	4057	4714	5359
75	3396	4198	4802
85	2165	2351	2104

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 2R 22 SEL45 UV FA 940 @700MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	677.40	N.A.	13.20
0-30	1427.58	N.A.	27.90
0-40	2317.75	N.A.	45.20
0-60	4047.56	N.A.	79.00
0-80	5040.28	N.A.	98.40
0-90	5122.64	N.A.	100.00
10-90	4946.49	N.A.	96.60
20-40	1640.35	N.A.	32.00
20-50	2551.26	N.A.	49.80
40-70	2359.09	N.A.	46.10
60-80	992.71	N.A.	19.40
70-80	363.44	N.A.	7.10
80-90	82.36	N.A.	1.60
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	5122.64	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	176.15
10-20	501.25
20-30	750.18
30-40	890.17
40-50	910.91
50-60	818.90
60-70	629.27
70-80	363.44
80-90	82.36
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 2R 22 SEL45 UV FA 940 @700MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	98	94	91	94	91	89	90	88	86	84
2	99	91	84	78	96	89	82	77	85	80	75	82	77	74	79	75	72	70
3	90	80	71	65	88	78	70	64	75	69	63	72	67	62	70	65	61	59
4	83	71	62	55	80	69	61	55	67	60	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	47	58	51	46	56	50	46	43
6	70	57	48	41	68	56	47	41	54	46	41	52	46	40	51	45	40	38
7	65	51	43	37	63	51	42	36	49	42	36	48	41	36	46	40	36	34
8	61	47	38	33	59	46	38	33	45	38	32	44	37	32	43	36	32	30
9	57	43	35	29	55	43	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	27	38	31	26	37	31	26	36	31	26	24


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 2R 22 SEL45 UV FA 940 @700MA.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	17.2	18.8	17.5	19.1	19.4	18.3	19.9	18.7	20.2	20.6
	3H	18.9	20.4	19.3	20.7	21.0	20.3	21.8	20.7	22.1	22.4
	4H	19.5	20.9	19.9	21.2	21.6	21.0	22.4	21.4	22.7	23.1
	6H	19.9	21.2	20.3	21.6	21.9	21.5	22.8	21.9	23.2	23.6
	8H	20.0	21.2	20.4	21.6	22.0	21.6	22.9	22.1	23.3	23.7
	12H	20.1	21.3	20.5	21.6	22.1	21.7	22.9	22.1	23.2	23.7
4H	2H	17.9	19.3	18.3	19.7	20.1	18.8	20.2	19.2	20.6	20.9
	3H	19.9	21.1	20.3	21.4	21.8	21.0	22.2	21.5	22.6	23.0
	4H	20.6	21.7	21.0	22.1	22.5	21.9	23.0	22.3	23.4	23.8
	6H	21.1	22.1	21.6	22.5	23.0	22.6	23.5	23.0	23.9	24.4
	8H	21.3	22.2	21.8	22.6	23.1	22.7	23.6	23.2	24.0	24.5
	12H	21.4	22.2	21.9	22.6	23.1	22.8	23.6	23.3	24.0	24.5
8H	4H	21.0	21.9	21.5	22.3	22.8	22.2	23.0	22.6	23.5	23.9
	6H	21.7	22.4	22.2	22.9	23.4	22.9	23.6	23.4	24.1	24.6
	8H	21.9	22.5	22.4	23.0	23.5	23.2	23.8	23.7	24.3	24.8
	12H	22.1	22.6	22.6	23.1	23.7	23.3	23.8	23.8	24.3	24.9
12H	4H	21.1	21.9	21.6	22.3	22.8	22.2	23.0	22.7	23.4	23.9
	6H	21.8	22.4	22.3	22.9	23.4	23.0	23.6	23.5	24.1	24.6
	8H	22.0	22.6	22.5	23.1	23.6	23.2	23.8	23.7	24.3	24.9

Maximum UGR = 24.9

POLAR GRAPH



Maximum Candela = 1864.021 Located At Horizontal Angle = 0, Vertical Angle = 0
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)