



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 2R 22 SEL45 UV FA 940 @850MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-031 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/4/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFL G2 2R 22 SEL45 UV FA 940

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflectors,

[MORE] two frosted linear ribbed plastic enclosures.

[LAMPCAT] Two LS3873A7_4000_90R 4000K 48 LED boards

[BALLAST] One KTLD-45-UV-PS850-54-VDIM-LM1 LED driver set to 850mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	6143
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	143
Total Luminaire Watts	42.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	5857	6264	6671
55	5406	5986	6590
65	4866	5654	6426
75	4072	5034	5759
85	2597	2819	2523

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 2R 22 SEL45 UV FA 940 @850MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	812.34	N.A.	13.20
0-30	1711.96	N.A.	27.90
0-40	2779.45	N.A.	45.20
0-60	4853.84	N.A.	79.00
0-80	6044.3	N.A.	98.40
0-90	6143.07	N.A.	100.00
10-90	5931.83	N.A.	96.60
20-40	1967.11	N.A.	32.00
20-50	3059.47	N.A.	49.80
40-70	2829.01	N.A.	46.10
60-80	1190.46	N.A.	19.40
70-80	435.84	N.A.	7.10
80-90	98.77	N.A.	1.60
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	6143.07	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	211.24
10-20	601.10
20-30	899.62
30-40	1067.49
40-50	1092.36
50-60	982.03
60-70	754.62
70-80	435.84
80-90	98.77
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	98	94	91	94	91	89	90	88	86	84
2	99	91	84	78	96	89	82	77	85	80	75	82	78	74	79	75	72	70
3	90	80	71	65	88	78	70	64	75	69	63	72	67	62	70	65	61	59
4	83	71	62	55	80	69	61	55	67	60	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	47	58	51	46	56	50	46	43
6	70	57	48	41	68	56	47	41	54	46	41	52	46	40	51	45	40	38
7	65	51	43	37	63	51	42	36	49	42	36	48	41	36	46	40	36	34
8	61	47	38	33	59	46	38	33	45	38	32	44	37	32	43	36	32	30
9	57	43	35	29	55	43	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	27	38	31	26	37	31	26	36	31	26	24

IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 2R 22 SEL45 UV FA 940 @850MA.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	17.8	19.4	18.1	19.7	20.0	18.9	20.5	19.3	20.8	21.2
	3H	19.5	21.0	19.9	21.3	21.6	20.9	22.4	21.3	22.7	23.0
	4H	20.1	21.5	20.5	21.8	22.2	21.6	23.0	22.0	23.3	23.7
	6H	20.5	21.8	20.9	22.2	22.5	22.1	23.4	22.5	23.8	24.2
	8H	20.6	21.8	21.0	22.2	22.6	22.2	23.5	22.7	23.9	24.3
	12H	20.7	21.9	21.1	22.2	22.7	22.3	23.5	22.7	23.8	24.3
4H	2H	18.5	19.9	18.9	20.3	20.7	19.4	20.8	19.8	21.2	21.5
	3H	20.5	21.6	20.9	22.0	22.4	21.6	22.8	22.1	23.2	23.6
	4H	21.2	22.3	21.6	22.7	23.1	22.5	23.6	22.9	24.0	24.4
	6H	21.7	22.7	22.2	23.1	23.6	23.2	24.1	23.6	24.5	25.0
	8H	21.9	22.8	22.4	23.2	23.7	23.3	24.2	23.8	24.6	25.1
	12H	22.0	22.8	22.5	23.2	23.7	23.4	24.2	23.9	24.6	25.1
8H	4H	21.6	22.5	22.1	22.9	23.4	22.8	23.6	23.2	24.1	24.5
	6H	22.3	23.0	22.8	23.5	24.0	23.5	24.2	24.0	24.7	25.2
	8H	22.5	23.1	23.0	23.6	24.1	23.8	24.4	24.3	24.9	25.4
	12H	22.7	23.2	23.2	23.7	24.3	23.9	24.4	24.4	24.9	25.5
12H	4H	21.7	22.5	22.2	22.9	23.4	22.8	23.6	23.3	24.0	24.5
	6H	22.4	23.0	22.9	23.5	24.0	23.6	24.2	24.1	24.7	25.2
	8H	22.6	23.2	23.1	23.7	24.2	23.8	24.4	24.3	24.9	25.5

Maximum UGR = 25.5

POLAR GRAPH



Maximum Candela = 2235.333 Located At Horizontal Angle = 0, Vertical Angle = 0
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)