



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 2R 24 SEL100 UV FA 930 @1500MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-030 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/4/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFL G2 2R 24 SEL100 UV FA 930

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflectors,  
[MORE] two frosted linear ribbed plastic enclosures.

[LAMPCAT] Four LS3873A8\_3000\_90R 3000K 64 LED boards

[BALLAST] One KTLD-100-UV-PS1800-54-VDIM-LM2 LED driver set to 1500mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	10947
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	150
Total Luminaire Watts	73.2
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	5067	5388	5673
55	4692	5171	5586
65	4241	4904	5432
75	3558	4407	4867
85	2248	2479	1848

**IES INDOOR REPORT****PHOTOMETRIC FILENAME : FFL G2 2R 24 SEL100 UV FA 930 @1500MA.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	1435.44	N.A.	13.10
0-30	3030.54	N.A.	27.70
0-40	4929.82	N.A.	45.00
0-60	8634.13	N.A.	78.90
0-80	10771.4	N.A.	98.40
0-90	10946.71	N.A.	100.00
10-90	10573.86	N.A.	96.60
20-40	3494.38	N.A.	31.90
20-50	5443.09	N.A.	49.70
40-70	5056.6	N.A.	46.20
60-80	2137.27	N.A.	19.50
70-80	784.97	N.A.	7.20
80-90	175.32	N.A.	1.60
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	10946.71	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	372.85
10-20	1062.58
20-30	1595.11
30-40	1899.28
40-50	1948.71
50-60	1755.6
60-70	1352.3
70-80	784.97
80-90	175.32
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 2R 24 SEL100 UV FA 930 @1500MA.IES

## COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	94	91	89	90	88	86	84
2	99	91	84	78	96	89	82	77	85	80	75	82	77	74	79	75	72	70
3	90	80	71	65	88	78	70	64	75	68	63	72	67	62	70	65	61	59
4	82	70	62	55	80	69	61	54	67	59	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	46	58	51	46	56	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41	52	45	40	51	45	40	38
7	65	51	43	36	63	51	42	36	49	41	36	48	41	36	46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32	44	37	32	42	36	32	30
9	56	43	35	29	55	42	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	26	38	31	26	37	31	26	36	30	26	24

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 2R 24 SEL100 UV FA 930 @1500MA.IES

## UGR TABLE - CORRECTED


### Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	17.3	18.9	17.7	19.3	19.6	18.3	19.9	18.7	20.2	20.6
	3H	19.0	20.5	19.4	20.8	21.2	20.3	21.8	20.6	22.1	22.4
	4H	19.7	21.0	20.1	21.4	21.8	21.0	22.4	21.4	22.8	23.1
	6H	20.1	21.4	20.5	21.7	22.1	21.5	22.8	21.9	23.2	23.6
	8H	20.2	21.4	20.6	21.8	22.2	21.6	22.9	22.0	23.3	23.7
	12H	20.2	21.4	20.7	21.8	22.2	21.7	22.8	22.1	23.2	23.7
4H	2H	18.1	19.5	18.5	19.8	20.2	18.9	20.3	19.3	20.6	21.0
	3H	20.0	21.2	20.5	21.6	22.0	21.1	22.2	21.5	22.6	23.0
	4H	20.8	21.8	21.2	22.3	22.7	21.9	23.0	22.4	23.4	23.9
	6H	21.3	22.3	21.8	22.7	23.2	22.6	23.5	23.0	24.0	24.4
	8H	21.5	22.3	21.9	22.8	23.3	22.7	23.6	23.2	24.1	24.5
	12H	21.6	22.4	22.0	22.8	23.3	22.8	23.6	23.3	24.1	24.5
8H	4H	21.2	22.1	21.6	22.5	23.0	22.2	23.1	22.7	23.5	24.0
	6H	21.9	22.6	22.4	23.1	23.5	23.0	23.7	23.5	24.2	24.7
	8H	22.1	22.7	22.6	23.2	23.7	23.2	23.8	23.7	24.3	24.8
	12H	22.2	22.8	22.7	23.3	23.9	23.3	23.8	23.8	24.3	24.9
12H	4H	21.2	22.0	21.7	22.5	23.0	22.2	23.0	22.7	23.5	24.0
	6H	22.0	22.6	22.5	23.1	23.6	23.0	23.7	23.5	24.1	24.7
	8H	22.2	22.8	22.7	23.3	23.8	23.3	23.8	23.8	24.3	24.9

Maximum UGR = 24.9

POLAR GRAPH



Maximum Candela = 3947.322 Located At Horizontal Angle = 67.5, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (67.5 - 247.5) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)