



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 2R 24 SEL35 UV FA 930 @550MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-030 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/4/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFL G2 2R 24 SEL35 UV FA 930

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflectors,

[MORE] two frosted linear ribbed plastic enclosures.

[LAMPCAT] Four LS3873A7\_3000\_90R 3000K 48 LED boards

[BALLAST] One KTLD-35-UV-PS650-54-VDIM-LM1 LED driver set to 550mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4003
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	153
Total Luminaire Watts	26.1
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1853	1970	2074
55	1716	1891	2043
65	1551	1793	1986
75	1301	1611	1780
85	822	906	676

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 2R 24 SEL35 UV FA 930 @550MA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	524.92	N.A.	13.10
0-30	1108.22	N.A.	27.70
0-40	1802.75	N.A.	45.00
0-60	3157.36	N.A.	78.90
0-80	3938.93	N.A.	98.40
0-90	4003.04	N.A.	100.00
10-90	3866.69	N.A.	96.60
20-40	1277.84	N.A.	31.90
20-50	1990.45	N.A.	49.70
40-70	1849.12	N.A.	46.20
60-80	781.57	N.A.	19.50
70-80	287.05	N.A.	7.20
80-90	64.11	N.A.	1.60
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	4003.04	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	136.35
10-20	388.57
20-30	583.30
30-40	694.53
40-50	712.61
50-60	641.99
60-70	494.51
70-80	287.05
80-90	64.11
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	94	91	89	90	88	86	84
2	99	91	84	78	96	89	82	77	85	80	75	82	77	74	79	75	72	70
3	90	80	71	65	88	78	70	64	75	68	63	72	67	62	70	65	61	59
4	82	70	62	55	80	69	61	54	67	59	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	46	58	51	46	56	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41	52	45	40	51	45	40	38
7	65	51	43	36	63	51	42	36	49	41	36	48	41	36	46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32	44	37	32	42	36	32	30
9	56	43	35	29	55	42	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	26	38	31	26	37	31	26	36	30	26	24

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 2R 24 SEL35 UV FA 930 @550MA.IES**

**UGR TABLE - CORRECTED**


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	13.8	15.4	14.2	15.8	16.1	14.8	16.4	15.2	16.7	17.1
	3H	15.5	17.0	15.9	17.3	17.7	16.8	18.3	17.1	18.6	18.9
	4H	16.2	17.5	16.6	17.9	18.3	17.5	18.9	17.9	19.3	19.6
	6H	16.6	17.9	17.0	18.2	18.6	18.0	19.3	18.4	19.7	20.1
	8H	16.7	17.9	17.1	18.3	18.7	18.1	19.4	18.5	19.8	20.2
	12H	16.7	17.9	17.2	18.3	18.7	18.2	19.3	18.6	19.7	20.2
4H	2H	14.6	16.0	15.0	16.3	16.7	15.4	16.8	15.8	17.1	17.5
	3H	16.5	17.7	17.0	18.1	18.5	17.6	18.7	18.0	19.1	19.5
	4H	17.3	18.3	17.7	18.8	19.2	18.5	19.5	18.9	19.9	20.4
	6H	17.8	18.8	18.3	19.2	19.7	19.1	20.0	19.5	20.5	20.9
	8H	18.0	18.9	18.4	19.3	19.8	19.2	20.1	19.7	20.6	21.0
	12H	18.1	18.9	18.5	19.3	19.8	19.3	20.1	19.8	20.6	21.0
8H	4H	17.7	18.6	18.1	19.0	19.5	18.7	19.6	19.2	20.0	20.5
	6H	18.4	19.1	18.9	19.6	20.0	19.5	20.2	20.0	20.7	21.2
	8H	18.6	19.2	19.1	19.7	20.2	19.7	20.3	20.2	20.8	21.3
	12H	18.7	19.3	19.2	19.8	20.4	19.8	20.3	20.3	20.8	21.4
12H	4H	17.7	18.5	18.2	19.0	19.5	18.7	19.5	19.2	20.0	20.5
	6H	18.5	19.1	19.0	19.6	20.1	19.5	20.2	20.0	20.6	21.2
	8H	18.7	19.3	19.2	19.8	20.3	19.8	20.3	20.3	20.8	21.4

Maximum UGR = 21.4

POLAR GRAPH



Maximum Candela = 1443.472 Located At Horizontal Angle = 67.5, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (67.5 - 247.5) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)