



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 2R 24 SEL35 UV FA 940 @600MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-030 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/4/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFL G2 2R 24 SEL35 UV FA 940

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflectors,
[MORE] two frosted linear ribbed plastic enclosures.

[LAMPCAT] Four LS3873A7_4000_90R 4000K 48 LED boards

[BALLAST] One KTLD-35-UV-PS650-54-VDIM-LM1 LED driver set to 600mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4494
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	157
Total Luminaire Watts	28.6
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2080	2212	2329
55	1926	2123	2293
65	1741	2013	2230
75	1461	1809	1998
85	923	1018	759

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 2R 24 SEL35 UV FA 940 @600MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	589.32	N.A.	13.10
0-30	1244.2	N.A.	27.70
0-40	2023.96	N.A.	45.00
0-60	3544.78	N.A.	78.90
0-80	4422.25	N.A.	98.40
0-90	4494.22	N.A.	100.00
10-90	4341.15	N.A.	96.60
20-40	1434.63	N.A.	31.90
20-50	2234.69	N.A.	49.70
40-70	2076.01	N.A.	46.20
60-80	877.47	N.A.	19.50
70-80	322.27	N.A.	7.20
80-90	71.98	N.A.	1.60
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	4494.22	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	153.08
10-20	436.25
20-30	654.88
30-40	779.76
40-50	800.05
50-60	720.77
60-70	555.19
70-80	322.28
80-90	71.98
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	94	91	89	90	88	86	84
2	99	91	84	78	96	89	82	77	85	80	75	82	77	74	79	75	72	70
3	90	80	71	65	88	78	70	64	75	68	63	72	67	62	70	65	61	59
4	82	70	62	55	80	69	61	54	67	59	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	46	58	51	46	56	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41	52	45	40	51	45	40	38
7	65	51	43	36	63	51	42	36	49	41	36	48	41	36	46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32	44	37	32	42	36	32	30
9	56	43	35	29	55	42	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	26	38	31	26	37	31	26	36	30	26	24


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 2R 24 SEL35 UV FA 940 @600MA.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	14.2	15.8	14.6	16.2	16.5	15.2	16.8	15.6	17.1	17.5
	3H	15.9	17.4	16.3	17.7	18.1	17.2	18.7	17.5	19.0	19.3
	4H	16.6	17.9	17.0	18.3	18.7	17.9	19.3	18.3	19.7	20.0
	6H	17.0	18.3	17.4	18.6	19.0	18.4	19.7	18.8	20.1	20.5
	8H	17.1	18.3	17.5	18.7	19.1	18.5	19.8	18.9	20.2	20.6
	12H	17.1	18.3	17.6	18.7	19.1	18.6	19.7	19.0	20.1	20.6
4H	2H	15.0	16.4	15.4	16.7	17.1	15.8	17.2	16.2	17.5	17.9
	3H	16.9	18.1	17.4	18.5	18.9	18.0	19.1	18.4	19.5	19.9
	4H	17.7	18.7	18.1	19.2	19.6	18.9	19.9	19.3	20.3	20.8
	6H	18.2	19.2	18.7	19.6	20.1	19.5	20.4	19.9	20.9	21.3
	8H	18.4	19.3	18.8	19.7	20.2	19.6	20.5	20.1	21.0	21.4
	12H	18.5	19.3	18.9	19.7	20.2	19.7	20.5	20.2	21.0	21.4
8H	4H	18.1	19.0	18.5	19.4	19.9	19.1	20.0	19.6	20.4	20.9
	6H	18.8	19.5	19.3	20.0	20.4	19.9	20.6	20.4	21.1	21.6
	8H	19.0	19.6	19.5	20.1	20.6	20.1	20.7	20.6	21.2	21.7
	12H	19.1	19.7	19.6	20.2	20.8	20.2	20.7	20.7	21.2	21.8
12H	4H	18.1	18.9	18.6	19.4	19.9	19.1	19.9	19.6	20.4	20.9
	6H	18.9	19.5	19.4	20.0	20.5	19.9	20.6	20.4	21.0	21.6
	8H	19.1	19.7	19.6	20.2	20.7	20.2	20.7	20.7	21.2	21.8

Maximum UGR = 21.8

POLAR GRAPH



Maximum Candela = 1620.591 Located At Horizontal Angle = 67.5, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (67.5 - 247.5) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)