



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 2R 24 SEL45 UV FA 935 @750MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-030 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/4/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFL G2 2R 24 SEL45 UV FA 935

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflectors,

[MORE] two frosted linear ribbed plastic enclosures.

[LAMPCAT] Four LS3873A7\_3500\_90R 3500K 48 LED boards

[BALLAST] One KTLD-45-UV-PS850-54-VDIM-LM1 LED driver set to 750mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	5500
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	152
Total Luminaire Watts	36.3
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2546	2707	2850
55	2357	2598	2806
65	2131	2464	2729
75	1788	2214	2445
85	1129	1245	929

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 2R 24 SEL45 UV FA 935 @750MA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	721.18	N.A.	13.10
0-30	1522.57	N.A.	27.70
0-40	2476.79	N.A.	45.00
0-60	4337.87	N.A.	78.90
0-80	5411.66	N.A.	98.40
0-90	5499.74	N.A.	100.00
10-90	5312.41	N.A.	96.60
20-40	1755.61	N.A.	31.90
20-50	2734.66	N.A.	49.70
40-70	2540.49	N.A.	46.20
60-80	1073.79	N.A.	19.50
70-80	394.38	N.A.	7.20
80-90	88.08	N.A.	1.60
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	5499.74	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	187.33
10-20	533.85
20-30	801.40
30-40	954.22
40-50	979.05
50-60	882.03
60-70	679.41
70-80	394.38
80-90	88.08
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT  
 PHOTOMETRIC FILENAME : FFL G2 2R 24 SEL45 UV FA 935 @750MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	97	94	91	94	91	89	90	88	86	84
2	99	91	84	78	96	89	82	77	85	80	75	82	77	74	79	75	72	70
3	90	80	71	65	88	78	70	64	75	68	63	72	67	62	70	65	61	59
4	82	70	62	55	80	69	61	54	67	59	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	46	58	51	46	56	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41	52	45	40	51	45	40	38
7	65	51	43	36	63	51	42	36	49	41	36	48	41	36	46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32	44	37	32	42	36	32	30
9	56	43	35	29	55	42	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	26	38	31	26	37	31	26	36	30	26	24


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 2R 24 SEL45 UV FA 935 @750MA.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	14.9	16.5	15.3	16.9	17.2	15.9	17.5	16.3	17.8	18.2
	3H	16.6	18.1	17.0	18.4	18.8	17.9	19.4	18.2	19.7	20.0
	4H	17.3	18.6	17.7	19.0	19.4	18.6	20.0	19.0	20.4	20.7
	6H	17.7	19.0	18.1	19.3	19.7	19.1	20.4	19.5	20.8	21.2
	8H	17.8	19.0	18.2	19.4	19.8	19.2	20.5	19.6	20.9	21.3
	12H	17.8	19.0	18.3	19.4	19.8	19.3	20.4	19.7	20.8	21.3
4H	2H	15.7	17.1	16.1	17.4	17.8	16.5	17.9	16.9	18.2	18.6
	3H	17.6	18.8	18.1	19.2	19.6	18.7	19.8	19.1	20.2	20.6
	4H	18.4	19.4	18.8	19.9	20.3	19.6	20.6	20.0	21.0	21.5
	6H	18.9	19.9	19.4	20.3	20.8	20.2	21.1	20.6	21.6	22.0
	8H	19.1	20.0	19.5	20.4	20.9	20.3	21.2	20.8	21.7	22.1
	12H	19.2	20.0	19.6	20.4	20.9	20.4	21.2	20.9	21.7	22.1
8H	4H	18.8	19.7	19.2	20.1	20.6	19.8	20.7	20.3	21.1	21.6
	6H	19.5	20.2	20.0	20.7	21.1	20.6	21.3	21.1	21.8	22.3
	8H	19.7	20.3	20.2	20.8	21.3	20.8	21.4	21.3	21.9	22.4
	12H	19.8	20.4	20.3	20.9	21.5	20.9	21.4	21.4	21.9	22.5
12H	4H	18.8	19.6	19.3	20.1	20.6	19.8	20.6	20.3	21.1	21.6
	6H	19.6	20.2	20.1	20.7	21.2	20.6	21.3	21.1	21.7	22.3
	8H	19.8	20.4	20.3	20.9	21.4	20.9	21.4	21.4	21.9	22.5

Maximum UGR = 22.5

POLAR GRAPH



Maximum Candela = 1983.174 Located At Horizontal Angle = 67.5, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (67.5 - 247.5) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)