



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 22 SEL25 UV FA 935 @450MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] LLIA001588-024 (s)
[TESTLAB] LightLab International Allentown, LLC
[ISSUE DATE] 6/3/2024
[MANUFAC] LumenFocus, LLC
[LUMCAT] FFL G2 22 SEL25 UV FA 935
[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflector,
[MORE] frosted linear ribbed plastic enclosure.
[LAMP] One LS3872A7_3500_90R 3500K 48 LED board
[BALLAST] One KTLD-25-UV-PS450-54-VDIM-LP2 LED driver set to 450mA
[OTHER] 120.0Vac, 60.01Hz
[OTHER] This test was performed using the absolute method of photometry.
[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	3082
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	132
Total Luminaire Watts	23.3
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2823	3047	3270
55	2599	2947	3316
65	2338	2899	3515
75	1967	2922	3850
85	1311	2487	3432

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 22 SEL25 UV FA 935 @450MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	393.76	N.A.	12.80
0-30	829.70	N.A.	26.90
0-40	1347.45	N.A.	43.70
0-60	2363.33	N.A.	76.70
0-80	3006.52	N.A.	97.60
0-90	3081.79	N.A.	100.00
10-90	2979.37	N.A.	96.70
20-40	953.69	N.A.	30.90
20-50	1485.2	N.A.	48.20
40-70	1405.18	N.A.	45.60
60-80	643.19	N.A.	20.90
70-80	253.89	N.A.	8.20
80-90	75.27	N.A.	2.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	3081.79	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	102.42
10-20	291.34
20-30	435.95
30-40	517.75
40-50	531.51
50-60	484.36
60-70	389.30
70-80	253.89
80-90	75.27
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
 PHOTOMETRIC FILENAME : FFL G2 22 SEL25 UV FA 935 @450MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	90	83	77	95	88	81	76	84	79	74	81	76	72	78	74	71	68
3	89	78	70	63	87	77	69	63	74	67	62	71	65	61	69	64	60	57
4	82	69	60	54	79	68	60	53	66	58	52	63	57	52	61	56	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	44	39	50	44	39	37
7	64	51	42	35	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	38	32	58	45	37	32	44	37	31	43	36	31	42	36	31	29
9	56	42	34	29	55	42	34	28	41	33	28	40	33	28	39	32	28	26
10	52	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	25	24


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 22 SEL25 UV FA 935 @450MA.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	15.1	16.7	15.4	17.0	17.4	16.5	18.2	16.9	18.5	18.8
	3H	16.8	18.3	17.2	18.6	19.0	18.9	20.4	19.3	20.7	21.1
	4H	17.4	18.9	17.8	19.2	19.6	19.9	21.4	20.3	21.7	22.1
	6H	17.9	19.2	18.3	19.6	19.9	20.8	22.2	21.3	22.5	22.9
	8H	18.0	19.3	18.4	19.6	20.0	21.2	22.5	21.6	22.9	23.2
	12H	18.1	19.3	18.5	19.7	20.1	21.4	22.6	21.9	23.0	23.4
4H	2H	16.0	17.4	16.3	17.7	18.1	17.1	18.5	17.5	18.9	19.2
	3H	17.9	19.1	18.3	19.5	19.9	19.7	20.9	20.1	21.3	21.7
	4H	18.7	19.8	19.1	20.2	20.6	20.9	22.0	21.3	22.4	22.8
	6H	19.3	20.2	19.7	20.6	21.1	22.0	23.0	22.5	23.4	23.9
	8H	19.4	20.3	19.9	20.7	21.2	22.4	23.3	22.9	23.8	24.2
	12H	19.5	20.3	20.0	20.8	21.3	22.7	23.5	23.2	24.0	24.5
8H	4H	19.3	20.2	19.7	20.6	21.1	21.2	22.1	21.7	22.5	23.0
	6H	20.0	20.8	20.5	21.2	21.7	22.5	23.2	23.0	23.7	24.2
	8H	20.2	20.9	20.7	21.4	21.9	23.0	23.7	23.5	24.2	24.7
	12H	20.4	21.0	20.9	21.5	22.1	23.4	24.0	23.9	24.5	25.0
12H	4H	19.4	20.2	19.9	20.7	21.2	21.2	22.0	21.7	22.5	23.0
	6H	20.2	20.9	20.7	21.3	21.9	22.5	23.2	23.0	23.7	24.2
	8H	20.5	21.1	21.0	21.6	22.1	23.1	23.7	23.6	24.2	24.7

Maximum UGR = 25.0

POLAR GRAPH



Maximum Candela = 1084.406 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)