



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 22 SEL45 UV FA 935 @750MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-024 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/3/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFL G2 22 SEL45 UV FA 935

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflector,
[MORE] frosted linear ribbed plastic enclosure.

[LAMP] One LS3872A7_3500_90R 3500K 64 LED board

[BALLAST] One KTLD-45-UV-PS850-54-VDIM-LM1 LED driver set to 750mA

[OTHER] 120.0Vac, 60.01Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4967
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	128
Total Luminaire Watts	38.7
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	4550	4910	5270
55	4188	4750	5345
65	3768	4672	5665
75	3171	4709	6205
85	2113	4009	5531

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 22 SEL45 UV FA 935 @750MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	634.64	N.A.	12.80
0-30	1337.28	N.A.	26.90
0-40	2171.75	N.A.	43.70
0-60	3809.09	N.A.	76.70
0-80	4845.75	N.A.	97.60
0-90	4967.07	N.A.	100.00
10-90	4802.00	N.A.	96.70
20-40	1537.11	N.A.	30.90
20-50	2393.77	N.A.	48.20
40-70	2264.79	N.A.	45.60
60-80	1036.66	N.A.	20.90
70-80	409.20	N.A.	8.20
80-90	121.32	N.A.	2.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	4967.07	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	165.07
10-20	469.57
20-30	702.64
30-40	834.48
40-50	856.66
50-60	780.67
60-70	627.46
70-80	409.20
80-90	121.32
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 22 SEL45 UV FA 935 @750MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	90	83	77	95	88	81	76	84	79	74	81	76	72	78	74	71	68
3	89	78	70	63	87	77	69	63	74	67	62	71	65	61	69	64	60	57
4	82	69	60	54	79	68	60	53	66	58	52	63	57	52	61	56	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	44	39	50	44	39	37
7	64	51	42	36	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	38	32	58	45	37	32	44	37	31	43	36	31	42	36	31	29
9	56	42	34	29	55	42	34	28	41	33	28	40	33	28	39	32	28	26
10	52	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	25	24


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 22 SEL45 UV FA 935 @750MA.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	16.8	18.4	17.1	18.7	19.1	18.2	19.9	18.6	20.2	20.5
	3H	18.5	20.0	18.9	20.3	20.7	20.6	22.1	21.0	22.4	22.8
	4H	19.1	20.6	19.5	20.9	21.3	21.6	23.1	22.0	23.4	23.8
	6H	19.6	20.9	20.0	21.3	21.6	22.5	23.9	23.0	24.2	24.6
	8H	19.7	21.0	20.1	21.3	21.7	22.9	24.2	23.3	24.6	24.9
	12H	19.8	21.0	20.2	21.4	21.8	23.1	24.3	23.6	24.7	25.1
4H	2H	17.7	19.1	18.0	19.4	19.8	18.8	20.2	19.2	20.6	20.9
	3H	19.6	20.8	20.0	21.2	21.6	21.4	22.6	21.8	23.0	23.4
	4H	20.4	21.5	20.8	21.9	22.3	22.6	23.7	23.0	24.1	24.5
	6H	21.0	21.9	21.4	22.3	22.8	23.7	24.7	24.2	25.1	25.6
	8H	21.1	22.0	21.6	22.4	22.9	24.1	25.0	24.6	25.5	25.9
	12H	21.2	22.0	21.7	22.5	23.0	24.4	25.2	24.9	25.7	26.2
8H	4H	21.0	21.9	21.4	22.3	22.8	22.9	23.8	23.4	24.2	24.7
	6H	21.7	22.5	22.2	22.9	23.4	24.2	24.9	24.7	25.4	25.9
	8H	21.9	22.6	22.4	23.1	23.6	24.7	25.4	25.2	25.9	26.4
	12H	22.1	22.7	22.6	23.2	23.8	25.1	25.7	25.6	26.2	26.7
12H	4H	21.1	21.9	21.6	22.4	22.9	22.9	23.7	23.4	24.2	24.7
	6H	21.9	22.6	22.4	23.0	23.6	24.2	24.9	24.7	25.4	25.9
	8H	22.2	22.8	22.7	23.3	23.8	24.8	25.4	25.3	25.9	26.4

Maximum UGR = 26.7

POLAR GRAPH



Maximum Candela = 1747.79 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)