



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 22 SEL35 UV FA 930 @500MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-024 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/3/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFL G2 22 SEL35 UV FA 930

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflector,  
[MORE] frosted linear ribbed plastic enclosure.

[LAMP] One LS3872A7\_3000\_90R 3000K 64 LED board

[BALLAST] One KTLD-35-UV-PS650-54-VDIM-LM1 LED driver set to 500mA

[OTHER] 120.0Vac, 60.01Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	3459
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	139
Total Luminaire Watts	24.8
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	3169	3420	3670
55	2917	3308	3722
65	2624	3254	3945
75	2208	3279	4321
85	1472	2792	3852

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 22 SEL35 UV FA 930 @500MA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	441.98	N.A.	12.80
0-30	931.32	N.A.	26.90
0-40	1512.47	N.A.	43.70
0-60	2652.77	N.A.	76.70
0-80	3374.73	N.A.	97.60
0-90	3459.22	N.A.	100.00
10-90	3344.26	N.A.	96.70
20-40	1070.49	N.A.	30.90
20-50	1667.1	N.A.	48.20
40-70	1577.27	N.A.	45.60
60-80	721.96	N.A.	20.90
70-80	284.98	N.A.	8.20
80-90	84.49	N.A.	2.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	3459.22	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	114.96
10-20	327.02
20-30	489.34
30-40	581.15
40-50	596.61
50-60	543.69
60-70	436.98
70-80	284.98
80-90	84.49
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT  
 PHOTOMETRIC FILENAME : FFL G2 22 SEL35 UV FA 930 @500MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	90	83	77	95	88	81	76	84	79	74	81	76	72	78	74	71	68
3	89	79	70	63	87	77	69	63	74	67	62	71	65	61	69	64	60	57
4	82	69	60	54	79	68	60	53	66	58	52	63	57	52	61	56	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	45	39	50	44	39	37
7	64	51	42	36	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	38	32	58	45	37	32	44	37	31	43	36	31	42	36	31	29
9	56	42	34	29	55	42	34	28	41	33	28	40	33	28	39	32	28	26
10	52	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	25	24


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFL G2 22 SEL35 UV FA 930 @500MA.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	15.5	17.1	15.8	17.4	17.8	16.9	18.6	17.3	18.9	19.2
	3H	17.2	18.7	17.6	19.0	19.4	19.3	20.8	19.7	21.1	21.5
	4H	17.8	19.3	18.2	19.6	20.0	20.3	21.8	20.7	22.1	22.5
	6H	18.3	19.6	18.7	20.0	20.3	21.2	22.6	21.7	22.9	23.3
	8H	18.4	19.7	18.8	20.0	20.4	21.6	22.9	22.0	23.3	23.6
	12H	18.5	19.7	18.9	20.1	20.5	21.8	23.0	22.3	23.4	23.8
4H	2H	16.4	17.8	16.7	18.1	18.5	17.5	18.9	17.9	19.3	19.6
	3H	18.3	19.5	18.7	19.9	20.3	20.1	21.3	20.5	21.7	22.1
	4H	19.1	20.2	19.5	20.6	21.0	21.3	22.4	21.7	22.8	23.2
	6H	19.7	20.6	20.1	21.0	21.5	22.4	23.4	22.9	23.8	24.3
	8H	19.8	20.7	20.3	21.1	21.6	22.8	23.7	23.3	24.2	24.6
	12H	19.9	20.7	20.4	21.2	21.7	23.1	23.9	23.6	24.4	24.9
8H	4H	19.7	20.6	20.1	21.0	21.5	21.6	22.5	22.1	22.9	23.4
	6H	20.4	21.2	20.9	21.6	22.1	22.9	23.6	23.4	24.1	24.6
	8H	20.6	21.3	21.1	21.8	22.3	23.4	24.1	23.9	24.6	25.1
	12H	20.8	21.4	21.3	21.9	22.5	23.8	24.4	24.3	24.9	25.4
12H	4H	19.8	20.6	20.3	21.1	21.6	21.6	22.4	22.1	22.9	23.4
	6H	20.6	21.3	21.1	21.7	22.3	22.9	23.6	23.4	24.1	24.6
	8H	20.9	21.5	21.4	22.0	22.5	23.5	24.1	24.0	24.6	25.1

Maximum UGR = 25.4

POLAR GRAPH



Maximum Candela = 1217.215 Located At Horizontal Angle = 90, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)