



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 22 SEL15 UV FA 940 @270MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-024 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/3/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFL G2 22 SEL15 UV FA 940

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflector,
[MORE] frosted linear ribbed plastic enclosure.

[LAMP] One LS3872A7_4000_90R 4000K 48 LED board

[BALLAST] One KTLD-15-UV-PS300-54-VDIM-LP1 LED driver set to 270mA

[OTHER] 120.0Vac, 60.01Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1940
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	138
Total Luminaire Watts	14.1
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1777	1918	2058
55	1636	1855	2087
65	1472	1824	2212
75	1238	1839	2423
85	825	1566	2160

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 22 SEL15 UV FA 940 @270MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	247.85	N.A.	12.80
0-30	522.25	N.A.	26.90
0-40	848.14	N.A.	43.70
0-60	1487.58	N.A.	76.70
0-80	1892.43	N.A.	97.60
0-90	1939.81	N.A.	100.00
10-90	1875.35	N.A.	96.70
20-40	600.30	N.A.	30.90
20-50	934.85	N.A.	48.20
40-70	884.48	N.A.	45.60
60-80	404.85	N.A.	20.90
70-80	159.81	N.A.	8.20
80-90	47.38	N.A.	2.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1939.81	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	64.46
10-20	183.38
20-30	274.40
30-40	325.89
40-50	334.56
50-60	304.88
60-70	245.04
70-80	159.81
80-90	47.38
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 22 SEL15 UV FA 940 @270MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	90	83	77	95	88	81	76	84	79	74	81	76	72	78	74	71	68
3	89	78	70	63	87	77	69	63	74	67	62	71	65	61	69	64	60	57
4	82	69	60	54	79	68	60	53	66	58	52	63	57	52	61	56	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	44	39	50	44	39	37
7	64	51	42	35	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	38	32	58	45	37	32	44	37	31	43	36	31	42	36	31	29
9	56	42	34	29	55	42	34	28	41	33	28	40	33	28	39	32	28	26
10	52	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	25	24


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 22 SEL15 UV FA 940 @270MA.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	13.5	15.1	13.8	15.4	15.8	14.9	16.6	15.3	16.9	17.2
	3H	15.2	16.7	15.6	17.0	17.4	17.3	18.8	17.7	19.1	19.5
	4H	15.8	17.3	16.2	17.6	18.0	18.3	19.8	18.7	20.1	20.5
	6H	16.3	17.6	16.7	18.0	18.3	19.2	20.6	19.7	20.9	21.3
	8H	16.4	17.7	16.8	18.0	18.4	19.6	20.9	20.0	21.2	21.6
	12H	16.5	17.7	16.9	18.1	18.5	19.8	21.0	20.3	21.4	21.8
4H	2H	14.4	15.8	14.7	16.1	16.5	15.5	16.9	15.9	17.2	17.6
	3H	16.3	17.5	16.7	17.9	18.3	18.1	19.3	18.5	19.7	20.1
	4H	17.1	18.2	17.5	18.6	19.0	19.3	20.4	19.7	20.8	21.2
	6H	17.6	18.6	18.1	19.0	19.5	20.4	21.4	20.9	21.8	22.3
	8H	17.8	18.7	18.3	19.1	19.6	20.8	21.7	21.3	22.2	22.6
	12H	17.9	18.7	18.4	19.2	19.7	21.1	21.9	21.6	22.4	22.9
8H	4H	17.7	18.6	18.1	19.0	19.5	19.6	20.5	20.1	20.9	21.4
	6H	18.4	19.2	18.9	19.6	20.1	20.9	21.6	21.4	22.1	22.6
	8H	18.6	19.3	19.1	19.8	20.3	21.4	22.1	21.9	22.6	23.1
	12H	18.8	19.4	19.3	19.9	20.5	21.8	22.4	22.3	22.9	23.4
12H	4H	17.8	18.6	18.3	19.1	19.6	19.6	20.4	20.1	20.9	21.4
	6H	18.6	19.3	19.1	19.7	20.3	20.9	21.6	21.4	22.1	22.6
	8H	18.9	19.5	19.4	20.0	20.5	21.5	22.1	22.0	22.6	23.1

Maximum UGR = 23.4

POLAR GRAPH



Maximum Candela = 682.572 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)