



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFL G2 22 SEL25 UV FA 935 @350MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-024 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/3/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFL G2 22 SEL25 UV FA 935

[LUMINAIRE] Recessed mounted, formed white painted steel housing/reflector,
[MORE] frosted linear ribbed plastic enclosure.

[LAMP] One LS3872A7_3500_90R 3500K 48 LED board

[BALLAST] One KTLD-25-UV-PS450-54-VDIM-LP2 LED driver set to 350mA

[OTHER] 120.0Vac, 60.01Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2440
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	137
Total Luminaire Watts	17.8
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.85 ft
Luminous Width (90-270)	1.85 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2235	2412	2588
55	2057	2333	2625
65	1851	2295	2782
75	1557	2313	3048
85	1038	1969	2717

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 22 SEL25 UV FA 935 @350MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	311.70	N.A.	12.80
0-30	656.80	N.A.	26.90
0-40	1066.65	N.A.	43.70
0-60	1870.83	N.A.	76.70
0-80	2379.98	N.A.	97.60
0-90	2439.57	N.A.	100.00
10-90	2358.5	N.A.	96.70
20-40	754.95	N.A.	30.90
20-50	1175.7	N.A.	48.20
40-70	1112.35	N.A.	45.60
60-80	509.16	N.A.	20.90
70-80	200.98	N.A.	8.20
80-90	59.59	N.A.	2.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	2439.57	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	81.07
10-20	230.63
20-30	345.10
30-40	409.85
40-50	420.75
50-60	383.43
60-70	308.18
70-80	200.98
80-90	59.59
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 22 SEL25 UV FA 935 @350MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	90	83	77	95	88	81	76	84	79	74	81	76	72	78	74	71	68
3	89	78	70	63	87	77	69	63	74	67	62	71	65	61	68	64	60	57
4	82	69	60	54	79	68	60	53	66	58	52	63	57	52	61	56	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	44	39	50	44	39	37
7	64	51	42	35	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	38	32	58	45	37	32	44	37	31	43	36	31	42	36	31	29
9	56	42	34	28	55	42	34	28	41	33	28	40	33	28	39	32	28	26
10	52	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	25	24


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFL G2 22 SEL25 UV FA 935 @350MA.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	14.3	15.9	14.6	16.2	16.6	15.7	17.4	16.1	17.7	18.0
	3H	16.0	17.5	16.4	17.8	18.2	18.1	19.6	18.5	19.9	20.3
	4H	16.6	18.1	17.0	18.4	18.8	19.1	20.6	19.5	20.9	21.3
	6H	17.1	18.4	17.5	18.8	19.1	20.0	21.4	20.5	21.7	22.1
	8H	17.2	18.5	17.6	18.8	19.2	20.4	21.7	20.8	22.1	22.4
	12H	17.3	18.5	17.7	18.9	19.3	20.6	21.8	21.1	22.2	22.6
4H	2H	15.2	16.6	15.6	16.9	17.3	16.3	17.7	16.7	18.1	18.4
	3H	17.1	18.3	17.5	18.7	19.1	18.9	20.1	19.3	20.5	20.9
	4H	17.9	19.0	18.3	19.4	19.8	20.1	21.2	20.5	21.6	22.1
	6H	18.5	19.4	18.9	19.8	20.3	21.2	22.2	21.7	22.6	23.1
	8H	18.6	19.5	19.1	20.0	20.4	21.6	22.5	22.1	23.0	23.4
	12H	18.7	19.5	19.2	20.0	20.5	21.9	22.7	22.4	23.2	23.7
8H	4H	18.5	19.4	18.9	19.8	20.3	20.4	21.3	20.9	21.7	22.2
	6H	19.2	20.0	19.7	20.4	20.9	21.7	22.4	22.2	22.9	23.4
	8H	19.4	20.1	19.9	20.6	21.1	22.2	22.9	22.7	23.4	23.9
	12H	19.6	20.2	20.1	20.7	21.3	22.6	23.2	23.1	23.7	24.2
12H	4H	18.6	19.4	19.1	19.9	20.4	20.4	21.2	20.9	21.7	22.2
	6H	19.4	20.1	19.9	20.5	21.1	21.7	22.4	22.2	22.9	23.4
	8H	19.7	20.3	20.2	20.8	21.4	22.3	22.9	22.8	23.4	23.9

Maximum UGR = 24.2

POLAR GRAPH



Maximum Candela = 858.425 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)