



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFR G2 14 SEL15 UV FA 930 @270MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-017 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/4/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFR G2 14 SEL15 UV FA 930

[LUMINAIRE] Retrofit kit installed in an A.L.P. EF-1x4-2L-23GA 1x4 housing,

[MORE] formed white painted steel reflectors, frosted linear ribbed plastic enclosure.

[LAMPCAT] Two LS3873A7\_3000\_90R 3000K 48 LED boards

[BALLAST] One KTLD-15-UV-PS300-54-VDIM-LP1 LED driver set to 270mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1943
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	142
Total Luminaire Watts	13.7
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.75 ft
Luminous Width (90-270)	0.75 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2313	2483	2639
55	2138	2372	2506
65	1928	2154	2218
75	1620	1758	1667
85	1067	640	327

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 14 SEL15 UV FA 930 @270MA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	261.40	N.A.	13.50
0-30	551.71	N.A.	28.40
0-40	897.23	N.A.	46.20
0-60	1565.31	N.A.	80.60
0-80	1919.41	N.A.	98.80
0-90	1942.53	N.A.	100.00
10-90	1874.62	N.A.	96.50
20-40	635.83	N.A.	32.70
20-50	989.69	N.A.	50.90
40-70	899.47	N.A.	46.30
60-80	354.09	N.A.	18.20
70-80	122.71	N.A.	6.30
80-90	23.13	N.A.	1.20
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1942.53	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	67.91
10-20	193.49
20-30	290.31
30-40	345.52
40-50	353.86
50-60	314.23
60-70	231.38
70-80	122.71
80-90	23.13
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 14 SEL15 UV FA 930 @270MA.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	97	106	102	98	95	98	95	92	94	92	89	90	88	87	85
2	99	91	85	79	97	89	83	78	86	81	76	83	78	74	80	76	73	71
3	91	80	72	66	88	79	71	65	76	69	64	73	68	63	70	66	62	60
4	83	71	62	56	81	70	62	55	67	60	55	65	59	54	63	58	53	51
5	76	64	55	48	74	63	54	48	60	53	47	58	52	47	57	51	46	44
6	71	57	48	42	69	56	48	42	55	47	42	53	46	41	51	45	41	39
7	65	52	43	37	64	51	43	37	50	42	37	48	42	37	47	41	36	34
8	61	47	39	33	59	47	39	33	45	38	33	44	38	33	43	37	32	31
9	57	44	35	30	56	43	35	30	42	35	30	41	34	29	40	34	29	28
10	53	40	32	27	52	40	32	27	39	32	27	38	31	27	37	31	27	25


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 14 SEL15 UV FA 930 @270MA.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	14.6	16.3	15.0	16.6	16.9	15.5	17.1	15.8	17.4	17.7
	3H	16.3	17.8	16.7	18.1	18.5	17.1	18.6	17.5	18.9	19.3
	4H	17.0	18.3	17.4	18.7	19.1	17.6	19.0	18.0	19.3	19.7
	6H	17.4	18.7	17.8	19.0	19.4	17.9	19.2	18.3	19.5	19.9
	8H	17.5	18.7	17.9	19.1	19.5	17.9	19.1	18.4	19.5	19.9
	12H	17.6	18.7	18.0	19.1	19.5	17.9	19.1	18.3	19.5	19.9
4H	2H	15.4	16.7	15.8	17.1	17.5	16.0	17.4	16.4	17.8	18.1
	3H	17.3	18.4	17.7	18.8	19.2	17.9	19.0	18.3	19.4	19.8
	4H	18.0	19.1	18.5	19.5	19.9	18.5	19.5	18.9	20.0	20.4
	6H	18.6	19.5	19.0	19.9	20.4	18.9	19.8	19.3	20.2	20.7
	8H	18.7	19.6	19.2	20.0	20.5	18.9	19.8	19.4	20.2	20.7
	12H	18.8	19.6	19.3	20.0	20.5	18.9	19.7	19.4	20.2	20.6
8H	4H	18.3	19.2	18.8	19.6	20.1	18.7	19.6	19.2	20.0	20.5
	6H	19.0	19.7	19.5	20.2	20.6	19.2	19.9	19.7	20.4	20.9
	8H	19.2	19.8	19.7	20.3	20.8	19.3	19.9	19.8	20.4	20.9
	12H	19.3	19.9	19.8	20.4	20.9	19.3	19.8	19.8	20.3	20.9
12H	4H	18.3	19.1	18.8	19.6	20.0	18.8	19.5	19.2	20.0	20.5
	6H	19.0	19.6	19.5	20.1	20.6	19.2	19.9	19.7	20.3	20.9
	8H	19.2	19.8	19.7	20.3	20.8	19.3	19.9	19.8	20.4	20.9

Maximum UGR = 20.9

POLAR GRAPH



Maximum Candela = 720.026 Located At Horizontal Angle = 90, Vertical Angle = 2  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)