



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFR G2 14 SEL45 UV FA 930 @750MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-017 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/4/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFR G2 14 SEL45 UV FA 930

[LUMINAIRE] Retrofit kit installed in an A.L.P. EF-1x4-2L-23GA 1x4 housing,

[MORE] formed white painted steel reflectors, frosted linear ribbed plastic enclosure.

[LAMPCAT] Two LS3873A7_3000_90R 3000K 48 LED boards

[BALLAST] One KTLD-45-UV-PS850-54-VDIM-LM1 LED driver set to 750mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	5360
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	143
Total Luminaire Watts	37.5
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.75 ft
Luminous Width (90-270)	0.75 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	6384	6853	7284
55	5901	6545	6915
65	5320	5944	6122
75	4469	4853	4601
85	2945	1767	903

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 14 SEL45 UV FA 930 @750MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	721.34	N.A.	13.50
0-30	1522.46	N.A.	28.40
0-40	2475.92	N.A.	46.20
0-60	4319.51	N.A.	80.60
0-80	5296.64	N.A.	98.80
0-90	5360.46	N.A.	100.00
10-90	5173.05	N.A.	96.50
20-40	1754.58	N.A.	32.70
20-50	2731.07	N.A.	50.90
40-70	2482.09	N.A.	46.30
60-80	977.13	N.A.	18.20
70-80	338.63	N.A.	6.30
80-90	63.82	N.A.	1.20
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	5360.46	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	187.41
10-20	533.93
20-30	801.12
30-40	953.46
40-50	976.48
50-60	867.11
60-70	638.50
70-80	338.63
80-90	63.82
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 14 SEL45 UV FA 930 @750MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	105	100	97	106	102	98	95	98	95	92	94	92	89	91	89	87	85
2	99	91	85	79	97	89	83	78	86	81	76	83	78	75	80	76	73	71
3	91	80	72	66	88	79	71	65	76	69	64	73	68	63	70	66	62	60
4	83	71	63	56	81	70	62	55	67	60	55	65	59	54	63	58	53	51
5	76	64	55	48	74	63	54	48	60	53	47	58	52	47	57	51	46	44
6	71	57	48	42	69	56	48	42	55	47	42	53	46	41	51	45	41	39
7	65	52	43	37	64	51	43	37	50	42	37	48	42	37	47	41	36	34
8	61	47	39	33	59	47	39	33	45	38	33	44	38	33	43	37	32	31
9	57	44	35	30	56	43	35	30	42	35	30	41	34	30	40	34	29	28
10	53	40	32	27	52	40	32	27	39	32	27	38	31	27	37	31	27	25


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 14 SEL45 UV FA 930 @750MA.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	18.1	19.8	18.5	20.1	20.4	19.0	20.6	19.3	20.9	21.2
	3H	19.8	21.3	20.2	21.6	22.0	20.6	22.1	21.0	22.4	22.8
	4H	20.5	21.8	20.9	22.2	22.6	21.1	22.5	21.5	22.8	23.2
	6H	20.9	22.2	21.3	22.5	22.9	21.4	22.7	21.8	23.0	23.4
	8H	21.0	22.2	21.4	22.6	23.0	21.4	22.6	21.9	23.0	23.4
	12H	21.1	22.2	21.5	22.6	23.0	21.4	22.6	21.8	23.0	23.4
4H	2H	18.9	20.2	19.3	20.6	21.0	19.5	20.9	19.9	21.2	21.6
	3H	20.8	21.9	21.2	22.3	22.7	21.4	22.5	21.8	22.9	23.3
	4H	21.5	22.6	22.0	23.0	23.4	22.0	23.0	22.4	23.5	23.9
	6H	22.1	23.0	22.5	23.4	23.9	22.4	23.3	22.8	23.7	24.2
	8H	22.2	23.1	22.7	23.5	24.0	22.4	23.3	22.9	23.7	24.2
	12H	22.3	23.1	22.8	23.5	24.0	22.4	23.2	22.9	23.7	24.1
8H	4H	21.8	22.7	22.3	23.1	23.6	22.2	23.1	22.7	23.5	24.0
	6H	22.5	23.2	23.0	23.7	24.1	22.7	23.4	23.2	23.9	24.4
	8H	22.7	23.3	23.2	23.8	24.3	22.8	23.4	23.3	23.9	24.4
	12H	22.8	23.4	23.3	23.9	24.4	22.8	23.3	23.3	23.8	24.4
12H	4H	21.8	22.6	22.3	23.1	23.5	22.3	23.0	22.7	23.5	24.0
	6H	22.5	23.1	23.0	23.6	24.1	22.7	23.4	23.2	23.8	24.4
	8H	22.7	23.3	23.2	23.8	24.3	22.8	23.4	23.3	23.9	24.4

Maximum UGR = 24.4

POLAR GRAPH



Maximum Candela = 1986.927 Located At Horizontal Angle = 90, Vertical Angle = 2
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)