



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFR G2 14 SEL25 UV FA 940 @400MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-017 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/4/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFR G2 14 SEL25 UV FA 940

[LUMINAIRE] Retrofit kit installed in an A.L.P. EF-1x4-2L-23GA 1x4 housing,

[MORE] formed white painted steel reflectors, frosted linear ribbed plastic enclosure.

[LAMPCAT] Two LS3873A7\_4000\_90R 4000K 48 LED boards

[BALLAST] One KTLD-25-UV-PS450-54-VDIM-LP2 LED driver set to 400mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2971
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	149
Total Luminaire Watts	19.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.75 ft
Luminous Width (90-270)	0.75 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	3538	3798	4037
55	3270	3628	3833
65	2949	3294	3393
75	2477	2689	2550
85	1632	979	501

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 14 SEL25 UV FA 940 @400MA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	399.79	N.A.	13.50
0-30	843.80	N.A.	28.40
0-40	1372.24	N.A.	46.20
0-60	2394.02	N.A.	80.60
0-80	2935.58	N.A.	98.80
0-90	2970.95	N.A.	100.00
10-90	2867.08	N.A.	96.50
20-40	972.45	N.A.	32.70
20-50	1513.65	N.A.	50.90
40-70	1375.66	N.A.	46.30
60-80	541.56	N.A.	18.20
70-80	187.68	N.A.	6.30
80-90	35.37	N.A.	1.20
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	2970.95	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	103.87
10-20	295.92
20-30	444.01
30-40	528.44
40-50	541.20
50-60	480.58
60-70	353.88
70-80	187.68
80-90	35.37
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 14 SEL25 UV FA 940 @400MA.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	105	100	97	106	102	98	95	98	95	92	94	92	89	91	88	87	85
2	99	91	85	79	97	89	83	78	86	81	76	83	78	75	80	76	73	71
3	91	80	72	66	88	79	71	65	76	69	64	73	68	63	70	66	62	60
4	83	71	63	56	81	70	62	55	67	60	55	65	59	54	63	58	53	51
5	76	64	55	48	74	63	54	48	60	53	47	58	52	47	57	51	46	44
6	71	57	48	42	69	56	48	42	55	47	42	53	46	41	51	45	41	39
7	65	52	43	37	64	51	43	37	50	42	37	48	42	37	47	41	36	34
8	61	47	39	33	59	47	39	33	45	38	33	44	38	33	43	37	32	31
9	57	44	35	30	56	43	35	30	42	35	30	41	34	30	40	34	29	28
10	53	40	32	27	52	40	32	27	39	32	27	38	31	27	37	31	27	25


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 14 SEL25 UV FA 940 @400MA.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	16.1	17.8	16.5	18.1	18.4	17.0	18.6	17.3	18.9	19.2
	3H	17.8	19.3	18.2	19.6	20.0	18.6	20.1	19.0	20.4	20.8
	4H	18.5	19.8	18.9	20.2	20.6	19.1	20.5	19.5	20.8	21.2
	6H	18.9	20.2	19.3	20.5	20.9	19.4	20.7	19.8	21.0	21.4
	8H	19.0	20.2	19.4	20.6	21.0	19.4	20.6	19.9	21.0	21.4
	12H	19.1	20.2	19.5	20.6	21.0	19.4	20.6	19.8	21.0	21.4
4H	2H	16.9	18.2	17.3	18.6	19.0	17.5	18.9	17.9	19.3	19.6
	3H	18.8	19.9	19.2	20.3	20.7	19.4	20.5	19.8	20.9	21.3
	4H	19.5	20.6	20.0	21.0	21.4	20.0	21.0	20.4	21.5	21.9
	6H	20.1	21.0	20.5	21.4	21.9	20.4	21.3	20.8	21.7	22.2
	8H	20.2	21.1	20.7	21.5	22.0	20.4	21.3	20.9	21.7	22.2
	12H	20.3	21.1	20.8	21.5	22.0	20.4	21.2	20.9	21.7	22.1
8H	4H	19.8	20.7	20.3	21.1	21.6	20.2	21.1	20.7	21.5	22.0
	6H	20.5	21.2	21.0	21.7	22.1	20.7	21.4	21.2	21.9	22.4
	8H	20.7	21.3	21.2	21.8	22.3	20.8	21.4	21.3	21.9	22.4
	12H	20.8	21.4	21.3	21.9	22.4	20.8	21.3	21.3	21.8	22.4
12H	4H	19.8	20.6	20.3	21.1	21.5	20.3	21.0	20.7	21.5	22.0
	6H	20.5	21.1	21.0	21.6	22.1	20.7	21.4	21.2	21.8	22.4
	8H	20.7	21.3	21.2	21.8	22.3	20.8	21.4	21.3	21.9	22.4

Maximum UGR = 22.4

POLAR GRAPH



Maximum Candela = 1101.224 Located At Horizontal Angle = 90, Vertical Angle = 2  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)