



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFR G2 22 SEL15 UV FA 930 @200MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-014 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/4/2024

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFR G2 22 SEL15 UV FA 930

[LUMINAIRE] Retrofit kit installed in an A.L.P. EL-2x2-20-2 2x2 housing,

[MORE] formed white painted steel reflectors, frosted linear ribbed plastic enclosure.

[LAMPCAT] One LS3872A7_3000_90R 3000K 48 LED board

[BALLAST] One KTLD-15-UV-PS300-54-VDIM-LP1 LED driver set to 200mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1438
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	140
Total Luminaire Watts	10.3
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.84 ft
Luminous Width (90-270)	1.84 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1308	1433	1562
55	1200	1394	1603
65	1074	1377	1709
75	908	1394	1927
85	654	1176	1318

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 22 SEL15 UV FA 930 @200MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	182.56	N.A.	12.70
0-30	384.69	N.A.	26.70
0-40	625.03	N.A.	43.50
0-60	1099.41	N.A.	76.40
0-80	1403.68	N.A.	97.60
0-90	1438.48	N.A.	100.00
10-90	1390.99	N.A.	96.70
20-40	442.46	N.A.	30.80
20-50	690.03	N.A.	48.00
40-70	657.48	N.A.	45.70
60-80	304.26	N.A.	21.20
70-80	121.17	N.A.	8.40
80-90	34.80	N.A.	2.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1438.48	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	47.49
10-20	135.07
20-30	202.13
30-40	240.33
40-50	247.56
50-60	226.82
60-70	183.10
70-80	121.17
80-90	34.80
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 22 SEL15 UV FA 930 @200MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	90	82	76	95	88	81	76	84	79	74	81	76	72	78	74	70	68
3	89	78	70	63	87	77	69	63	74	67	62	71	65	60	68	64	59	57
4	82	69	60	53	79	68	60	53	65	58	52	63	57	52	61	55	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	50	44	39	37
7	64	50	42	35	62	50	41	35	48	40	35	47	40	35	45	39	34	32
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	41	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	39	31	26	38	30	26	37	30	25	36	30	25	24


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 22 SEL15 UV FA 930 @200MA.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	12.4	14.1	12.8	14.4	14.7	14.1	15.8	14.5	16.1	16.4
	3H	14.1	15.6	14.5	16.0	16.3	16.5	18.0	16.9	18.4	18.7
	4H	14.7	16.2	15.1	16.5	16.9	17.6	19.0	18.0	19.4	19.7
	6H	15.2	16.5	15.6	16.9	17.3	18.5	19.9	19.0	20.2	20.6
	8H	15.3	16.6	15.8	17.0	17.4	18.9	20.1	19.3	20.5	20.9
	12H	15.4	16.6	15.8	17.0	17.4	19.0	20.2	19.4	20.6	21.0
4H	2H	13.3	14.7	13.7	15.1	15.5	14.6	16.1	15.0	16.4	16.8
	3H	15.3	16.5	15.7	16.9	17.3	17.3	18.5	17.7	18.9	19.3
	4H	16.0	17.1	16.5	17.5	18.0	18.6	19.7	19.0	20.1	20.5
	6H	16.6	17.6	17.0	18.0	18.5	19.7	20.7	20.1	21.1	21.6
	8H	16.8	17.7	17.3	18.1	18.6	20.1	21.0	20.5	21.4	21.9
	12H	16.9	17.7	17.4	18.2	18.7	20.3	21.1	20.8	21.6	22.0
8H	4H	16.7	17.6	17.1	18.0	18.5	18.8	19.7	19.3	20.2	20.6
	6H	17.4	18.2	17.9	18.7	19.1	20.2	20.9	20.6	21.4	21.9
	8H	17.7	18.4	18.2	18.9	19.3	20.6	21.3	21.1	21.8	22.3
	12H	17.9	18.5	18.4	19.0	19.5	20.9	21.5	21.4	22.0	22.6
12H	4H	16.8	17.6	17.3	18.1	18.6	18.9	19.7	19.3	20.2	20.6
	6H	17.6	18.3	18.2	18.8	19.3	20.2	20.9	20.7	21.3	21.9
	8H	18.0	18.6	18.5	19.1	19.6	20.7	21.3	21.2	21.8	22.4

Maximum UGR = 22.6

POLAR GRAPH



Maximum Candela = 503.529 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)