



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFR G2 22 SEL35 UV FA 940 @650MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] LLIA001588-014 (s)
[TESTLAB] LightLab International Allentown, LLC
[ISSUE DATE] 6/4/2024
[MANUFAC] Lumen Focus, LLC
[LUMCAT] FFR G2 22 SEL35 UV FA 940
[LUMINAIRE] Retrofit kit installed in an A.L.P. EL-2x2-20-2 2x2 housing,
[MORE] formed white painted steel reflectors, frosted linear ribbed plastic enclosure.
[LAMPCAT] One LS3872A8_4000_90R 4000K 64 LED board
[BALLAST] One KTLD-35-UV-PS650-54-VDIM-LM1 LED driver set to 650mA
[OTHER] 120.0Vac, 60.00Hz
[OTHER] This test was performed using the absolute method of photometry.
[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4643
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	142
Total Luminaire Watts	32.8
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.84 ft
Luminous Width (90-270)	1.84 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	4222	4627	5042
55	3873	4498	5175
65	3467	4445	5516
75	2932	4499	6219
85	2112	3797	4253

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 22 SEL35 UV FA 940 @650MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	589.27	N.A.	12.70
0-30	1241.69	N.A.	26.70
0-40	2017.42	N.A.	43.50
0-60	3548.6	N.A.	76.40
0-80	4530.68	N.A.	97.60
0-90	4643.02	N.A.	100.00
10-90	4489.73	N.A.	96.70
20-40	1428.15	N.A.	30.80
20-50	2227.22	N.A.	48.00
40-70	2122.17	N.A.	45.70
60-80	982.08	N.A.	21.20
70-80	391.09	N.A.	8.40
80-90	112.34	N.A.	2.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	4643.02	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	153.28
10-20	435.98
20-30	652.42
30-40	775.73
40-50	799.07
50-60	732.11
60-70	590.99
70-80	391.09
80-90	112.34
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 22 SEL35 UV FA 940 @650MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	90	82	76	95	88	81	76	84	79	74	81	76	72	78	74	70	68
3	89	78	70	63	87	77	69	63	74	67	62	71	65	60	68	64	59	57
4	82	69	60	53	79	68	60	53	65	58	52	63	57	52	61	55	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	50	44	39	37
7	64	50	42	35	62	50	41	35	48	40	35	47	40	35	45	39	34	32
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	41	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	39	31	26	37	30	26	37	30	25	36	30	25	24


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 22 SEL35 UV FA 940 @650MA.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	16.4	18.1	16.8	18.4	18.7	18.1	19.8	18.5	20.1	20.4
	3H	18.1	19.6	18.5	20.0	20.3	20.5	22.0	20.9	22.4	22.7
	4H	18.7	20.2	19.1	20.5	20.9	21.6	23.0	22.0	23.4	23.7
	6H	19.2	20.5	19.6	20.9	21.3	22.5	23.9	23.0	24.2	24.6
	8H	19.3	20.6	19.8	21.0	21.4	22.9	24.1	23.3	24.5	24.9
	12H	19.4	20.6	19.8	21.0	21.4	23.0	24.2	23.4	24.6	25.0
4H	2H	17.3	18.7	17.7	19.1	19.5	18.6	20.1	19.0	20.4	20.8
	3H	19.3	20.5	19.7	20.9	21.3	21.3	22.5	21.7	22.9	23.3
	4H	20.0	21.1	20.5	21.5	22.0	22.6	23.7	23.0	24.1	24.5
	6H	20.6	21.6	21.0	22.0	22.5	23.7	24.7	24.1	25.1	25.6
	8H	20.8	21.7	21.3	22.1	22.6	24.1	25.0	24.5	25.4	25.9
	12H	20.9	21.7	21.4	22.2	22.7	24.3	25.1	24.8	25.6	26.0
8H	4H	20.7	21.6	21.1	22.0	22.5	22.8	23.7	23.3	24.2	24.6
	6H	21.4	22.2	21.9	22.7	23.1	24.2	24.9	24.6	25.4	25.9
	8H	21.7	22.4	22.2	22.9	23.3	24.6	25.3	25.1	25.8	26.3
	12H	21.9	22.5	22.4	23.0	23.5	24.9	25.5	25.4	26.0	26.6
12H	4H	20.8	21.6	21.3	22.1	22.6	22.9	23.7	23.3	24.2	24.6
	6H	21.6	22.3	22.2	22.8	23.3	24.2	24.9	24.7	25.3	25.9
	8H	22.0	22.6	22.5	23.1	23.6	24.7	25.3	25.2	25.8	26.4

Maximum UGR = 26.6

POLAR GRAPH



Maximum Candela = 1625.254 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)