



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFR G2 22 SEL45 UV FA 930 @700MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-014 (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/4/2024

[MANUFAC] Lumen Focus, LLC

[LUMCAT] FFR G2 22 SEL45 UV FA 930

[LUMINAIRE] Retrofit kit installed in an A.L.P. EL-2x2-20-2 2x2 housing,

[MORE] formed white painted steel reflectors, frosted linear ribbed plastic enclosure.

[LAMPCAT] One LS3872A8\_3000\_90R 3000K 64 LED board

[BALLAST] One KTLD-45-UV-PS850-54-VDIM-LM1 LED driver set to 700mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4810
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	134
Total Luminaire Watts	35.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.84 ft
Luminous Width (90-270)	1.84 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	4374	4793	5223
55	4012	4659	5360
65	3592	4604	5714
75	3037	4660	6442
85	2188	3933	4406

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 22 SEL45 UV FA 930 @700MA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	610.40	N.A.	12.70
0-30	1286.21	N.A.	26.70
0-40	2089.76	N.A.	43.50
0-60	3675.85	N.A.	76.40
0-80	4693.15	N.A.	97.60
0-90	4809.52	N.A.	100.00
10-90	4650.74	N.A.	96.70
20-40	1479.37	N.A.	30.80
20-50	2307.09	N.A.	48.00
40-70	2198.27	N.A.	45.70
60-80	1017.3	N.A.	21.20
70-80	405.12	N.A.	8.40
80-90	116.37	N.A.	2.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	4809.52	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	158.78
10-20	451.62
20-30	675.82
30-40	803.55
40-50	827.72
50-60	758.36
60-70	612.18
70-80	405.12
80-90	116.37
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 22 SEL45 UV FA 930 @700MA.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	90	82	76	95	88	81	76	84	79	74	81	76	72	78	74	70	68
3	89	78	70	63	87	77	69	63	74	67	62	71	65	60	68	64	59	57
4	82	69	60	53	79	68	60	53	65	58	52	63	57	52	61	55	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	50	44	39	37
7	64	50	42	35	62	50	41	35	48	40	35	47	40	35	45	39	34	32
8	60	46	37	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	41	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	26	37	30	25	36	30	25	24


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 22 SEL45 UV FA 930 @700MA.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	16.6	18.3	17.0	18.6	18.9	18.3	20.0	18.7	20.3	20.6
	3H	18.3	19.8	18.7	20.2	20.5	20.7	22.2	21.1	22.6	22.9
	4H	18.9	20.4	19.3	20.7	21.1	21.8	23.2	22.2	23.6	23.9
	6H	19.4	20.7	19.8	21.1	21.5	22.7	24.1	23.2	24.4	24.8
	8H	19.5	20.8	20.0	21.2	21.6	23.1	24.3	23.5	24.7	25.1
	12H	19.6	20.8	20.0	21.2	21.6	23.2	24.4	23.6	24.8	25.2
4H	2H	17.5	18.9	17.9	19.3	19.7	18.8	20.3	19.2	20.6	21.0
	3H	19.5	20.7	19.9	21.1	21.5	21.5	22.7	21.9	23.1	23.5
	4H	20.2	21.3	20.7	21.7	22.2	22.8	23.9	23.2	24.3	24.7
	6H	20.8	21.8	21.2	22.2	22.7	23.9	24.9	24.3	25.3	25.8
	8H	21.0	21.9	21.5	22.3	22.8	24.3	25.2	24.7	25.6	26.1
	12H	21.1	21.9	21.6	22.4	22.9	24.5	25.3	25.0	25.8	26.2
8H	4H	20.9	21.8	21.3	22.2	22.7	23.0	23.9	23.5	24.4	24.8
	6H	21.6	22.4	22.1	22.9	23.3	24.4	25.1	24.8	25.6	26.1
	8H	21.9	22.6	22.4	23.1	23.5	24.8	25.5	25.3	26.0	26.5
	12H	22.1	22.7	22.6	23.2	23.7	25.1	25.7	25.6	26.2	26.8
12H	4H	21.0	21.8	21.5	22.3	22.8	23.1	23.9	23.5	24.4	24.8
	6H	21.8	22.5	22.4	23.0	23.5	24.4	25.1	24.9	25.5	26.1
	8H	22.2	22.8	22.7	23.3	23.8	24.9	25.5	25.4	26.0	26.6

Maximum UGR = 26.8

POLAR GRAPH



Maximum Candela = 1683.537 Located At Horizontal Angle = 90, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)