



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFR G2 24 SEL35 UV FA 940 @650MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-007A (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/4/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFR G2 24 SEL35 UV FA 940

[LUMINAIRE] Retrofit kit installed in an A.L.P. EL-2x4-23-2 2x4 housing,

[MORE] formed white painted steel reflectors, frosted linear ribbed plastic enclosure.

[LAMP] Two LS3873A7_4000_90R 4000K 48 LED boards

[BALLAST] One KTLD-35-UV-PS650-54-VDIM-LM1 LED driver set to 650mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4861
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	152
Total Luminaire Watts	31.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.75 ft
Luminous Width (90-270)	1.75 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2308	2512	2712
55	2120	2451	2780
65	1899	2434	2949
75	1594	2497	3298
85	1076	2192	2274

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 24 SEL35 UV FA 940 @650MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	612.59	N.A.	12.60
0-30	1292.92	N.A.	26.60
0-40	2103.8	N.A.	43.30
0-60	3708.6	N.A.	76.30
0-80	4741.04	N.A.	97.50
0-90	4861.28	N.A.	100.00
10-90	4702.12	N.A.	96.70
20-40	1491.21	N.A.	30.70
20-50	2328.1	N.A.	47.90
40-70	2225.59	N.A.	45.80
60-80	1032.45	N.A.	21.20
70-80	411.65	N.A.	8.50
80-90	120.23	N.A.	2.50
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	4861.28	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	159.16
10-20	453.43
20-30	680.33
30-40	810.88
40-50	836.89
50-60	767.91
60-70	620.79
70-80	411.65
80-90	120.23
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 24 SEL35 UV FA 940 @650MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	89	82	76	95	88	81	75	84	78	74	81	76	72	78	74	70	68
3	89	78	70	63	87	77	69	63	74	67	61	71	65	60	68	63	59	57
4	82	69	60	53	79	68	59	53	65	58	52	63	57	51	61	55	51	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	45	55	49	44	42
6	69	56	46	40	67	55	46	40	53	45	39	51	44	39	49	43	39	37
7	64	50	41	35	62	50	41	35	48	40	35	47	40	35	45	39	34	32
8	60	46	37	31	58	45	37	31	44	36	31	43	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	36	30	25	23


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 24 SEL35 UV FA 940 @650MA.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	14.4	16.0	14.7	16.4	16.7	16.0	17.7	16.4	18.0	18.3
	3H	16.1	17.6	16.5	17.9	18.3	18.4	19.9	18.8	20.2	20.6
	4H	16.7	18.2	17.1	18.5	18.9	19.4	20.9	19.8	21.2	21.6
	6H	17.2	18.5	17.6	18.9	19.3	20.4	21.7	20.8	22.1	22.4
	8H	17.3	18.6	17.7	19.0	19.4	20.7	21.9	21.1	22.3	22.7
	12H	17.4	18.6	17.8	19.0	19.4	20.8	22.0	21.2	22.4	22.8
4H	2H	15.3	16.7	15.7	17.1	17.4	16.6	18.0	16.9	18.3	18.7
	3H	17.3	18.5	17.7	18.9	19.3	19.2	20.4	19.6	20.8	21.2
	4H	18.0	19.1	18.5	19.5	20.0	20.4	21.5	20.9	21.9	22.4
	6H	18.6	19.6	19.0	20.0	20.5	21.5	22.5	22.0	22.9	23.4
	8H	18.8	19.7	19.3	20.1	20.6	21.9	22.8	22.4	23.2	23.7
	12H	18.9	19.7	19.4	20.2	20.7	22.1	22.9	22.6	23.4	23.9
8H	4H	18.7	19.6	19.2	20.0	20.5	20.7	21.6	21.2	22.1	22.5
	6H	19.5	20.2	19.9	20.7	21.2	22.0	22.8	22.5	23.3	23.7
	8H	19.7	20.4	20.2	20.9	21.4	22.5	23.1	23.0	23.7	24.1
	12H	19.9	20.5	20.4	21.0	21.6	22.8	23.4	23.3	23.9	24.4
12H	4H	18.8	19.6	19.3	20.1	20.6	20.8	21.6	21.2	22.1	22.5
	6H	19.7	20.4	20.2	20.8	21.3	22.1	22.8	22.6	23.2	23.8
	8H	20.0	20.6	20.5	21.1	21.7	22.6	23.2	23.1	23.7	24.2

Maximum UGR = 24.4

POLAR GRAPH



Maximum Candela = 1686.176 Located At Horizontal Angle = 90, Vertical Angle = 1.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (1.5) (Through Max. Cd.)