



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFR G2 24 SEL45 UV FA 930 @800MA.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-007A (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/4/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFR G2 24 SEL45 UV FA 930

[LUMINAIRE] Retrofit kit installed in an A.L.P. EL-2x4-23-2 2x4 housing,

[MORE] formed white painted steel reflectors, frosted linear ribbed plastic enclosure.

[LAMP] Two LS3873A7\_3000\_90R 3000K 48 LED boards

[BALLAST] One KTLD-45-UV-PS850-54-VDIM-LM1 LED driver set to 800mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	5760
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	143
Total Luminaire Watts	40.2
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.75 ft
Luminous Width (90-270)	1.75 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2734	2977	3213
55	2512	2904	3294
65	2250	2883	3494
75	1888	2959	3907
85	1274	2597	2694



**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 24 SEL45 UV FA 930 @800MA.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	725.80	N.A.	12.60
0-30	1531.85	N.A.	26.60
0-40	2492.58	N.A.	43.30
0-60	4393.94	N.A.	76.30
0-80	5617.17	N.A.	97.50
0-90	5759.63	N.A.	100.00
10-90	5571.05	N.A.	96.70
20-40	1766.78	N.A.	30.70
20-50	2758.32	N.A.	47.90
40-70	2636.87	N.A.	45.80
60-80	1223.24	N.A.	21.20
70-80	487.73	N.A.	8.50
80-90	142.45	N.A.	2.50
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	5759.63	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	188.57
10-20	537.22
20-30	806.05
30-40	960.73
40-50	991.54
50-60	909.82
60-70	735.51
70-80	487.73
80-90	142.45
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00



**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 24 SEL45 UV FA 930 @800MA.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	89	82	76	95	88	81	75	84	78	74	81	76	72	78	74	70	68
3	89	78	70	63	87	77	69	63	74	67	61	71	65	60	68	63	59	57
4	82	69	60	53	79	68	59	53	65	58	52	63	57	51	61	55	51	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	45	55	49	44	42
6	69	56	46	40	67	55	46	40	53	45	39	51	44	39	49	43	39	37
7	64	50	41	35	62	50	41	35	48	40	35	47	40	35	45	39	34	32
8	60	46	37	31	58	45	37	31	44	36	31	43	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	36	30	25	23



**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FFR G2 24 SEL45 UV FA 930 @800MA.IES**


**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	15.0	16.6	15.3	17.0	17.3	16.6	18.3	17.0	18.6	18.9
	3H	16.7	18.2	17.1	18.5	18.9	19.0	20.5	19.4	20.8	21.2
	4H	17.3	18.8	17.7	19.1	19.5	20.0	21.5	20.4	21.8	22.2
	6H	17.8	19.1	18.2	19.5	19.9	21.0	22.3	21.4	22.7	23.0
	8H	17.9	19.2	18.3	19.6	20.0	21.3	22.5	21.7	22.9	23.3
	12H	18.0	19.2	18.4	19.6	20.0	21.4	22.6	21.8	23.0	23.4
4H	2H	15.9	17.3	16.3	17.7	18.0	17.2	18.6	17.5	18.9	19.3
	3H	17.9	19.1	18.3	19.5	19.9	19.8	21.0	20.2	21.4	21.8
	4H	18.6	19.7	19.1	20.1	20.6	21.0	22.1	21.5	22.5	23.0
	6H	19.2	20.2	19.6	20.6	21.1	22.1	23.1	22.6	23.5	24.0
	8H	19.4	20.3	19.9	20.7	21.2	22.5	23.4	23.0	23.8	24.3
	12H	19.5	20.3	20.0	20.8	21.3	22.7	23.5	23.2	24.0	24.5
8H	4H	19.3	20.2	19.8	20.6	21.1	21.3	22.2	21.8	22.7	23.1
	6H	20.1	20.8	20.5	21.3	21.8	22.6	23.4	23.1	23.9	24.3
	8H	20.3	21.0	20.8	21.5	22.0	23.1	23.7	23.6	24.3	24.7
	12H	20.5	21.1	21.0	21.6	22.2	23.4	24.0	23.9	24.5	25.0
12H	4H	19.4	20.2	19.9	20.7	21.2	21.4	22.2	21.8	22.7	23.1
	6H	20.3	21.0	20.8	21.4	21.9	22.7	23.4	23.2	23.8	24.4
	8H	20.6	21.2	21.1	21.7	22.3	23.2	23.8	23.7	24.3	24.8

Maximum UGR = 25.0



POLAR GRAPH



Maximum Candela = 1997.776 Located At Horizontal Angle = 90, Vertical Angle = 1.5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (1.5) (Through Max. Cd.)