



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFR G2 24 SEL45 UV FA 935 @700MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-007A (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 6/4/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFR G2 24 SEL45 UV FA 935

[LUMINAIRE] Retrofit kit installed in an A.L.P. EL-2x4-23-2 2x4 housing,

[MORE] formed white painted steel reflectors, frosted linear ribbed plastic enclosure.

[LAMP] Two LS3873A7_3500_90R 3500K 48 LED boards

[BALLAST] One KTLD-45-UV-PS850-54-VDIM-LM1 LED driver set to 700mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	5099
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	146
Total Luminaire Watts	34.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.75 ft
Luminous Width (90-270)	1.75 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2421	2636	2845
55	2224	2572	2916
65	1992	2553	3093
75	1672	2620	3459
85	1128	2299	2385

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 24 SEL45 UV FA 935 @700MA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	642.60	N.A.	12.60
0-30	1356.26	N.A.	26.60
0-40	2206.87	N.A.	43.30
0-60	3890.28	N.A.	76.30
0-80	4973.3	N.A.	97.50
0-90	5099.42	N.A.	100.00
10-90	4932.47	N.A.	96.70
20-40	1564.26	N.A.	30.70
20-50	2442.15	N.A.	47.90
40-70	2334.62	N.A.	45.80
60-80	1083.02	N.A.	21.20
70-80	431.82	N.A.	8.50
80-90	126.12	N.A.	2.50
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	5099.42	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	166.96
10-20	475.64
20-30	713.66
30-40	850.61
40-50	877.88
50-60	805.53
60-70	651.20
70-80	431.82
80-90	126.12
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 24 SEL45 UV FA 935 @700MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	89	82	76	95	88	81	75	84	78	74	81	76	72	78	74	70	68
3	89	78	70	63	87	77	69	63	74	67	61	71	65	60	68	63	59	57
4	82	69	60	53	79	68	59	53	65	58	52	63	57	51	61	55	51	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	45	55	49	44	42
6	69	56	46	40	67	55	46	40	53	45	39	51	44	39	49	43	39	37
7	64	50	41	35	62	50	41	35	48	40	35	47	40	35	45	39	34	32
8	60	46	37	31	58	45	37	31	44	36	31	43	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	36	30	25	23

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 24 SEL45 UV FA 935 @700MA.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	14.6	16.2	14.9	16.6	16.9	16.2	17.9	16.6	18.2	18.5
	3H	16.3	17.8	16.7	18.1	18.5	18.6	20.1	19.0	20.4	20.8
	4H	16.9	18.4	17.3	18.7	19.1	19.6	21.1	20.0	21.4	21.8
	6H	17.4	18.7	17.8	19.1	19.5	20.6	21.9	21.0	22.3	22.6
	8H	17.5	18.8	17.9	19.2	19.6	20.9	22.1	21.3	22.5	22.9
	12H	17.6	18.8	18.0	19.2	19.6	21.0	22.2	21.4	22.6	23.0
4H	2H	15.5	16.9	15.9	17.3	17.6	16.8	18.2	17.2	18.5	18.9
	3H	17.5	18.7	17.9	19.1	19.5	19.4	20.6	19.8	21.0	21.4
	4H	18.2	19.3	18.7	19.7	20.2	20.6	21.7	21.1	22.1	22.6
	6H	18.8	19.8	19.3	20.2	20.7	21.7	22.7	22.2	23.1	23.6
	8H	19.0	19.9	19.5	20.3	20.8	22.1	23.0	22.6	23.4	23.9
	12H	19.1	19.9	19.6	20.4	20.9	22.3	23.1	22.8	23.6	24.1
8H	4H	18.9	19.8	19.4	20.2	20.7	20.9	21.8	21.4	22.3	22.7
	6H	19.7	20.4	20.1	20.9	21.4	22.2	23.0	22.7	23.5	23.9
	8H	19.9	20.6	20.4	21.1	21.6	22.7	23.3	23.2	23.9	24.3
	12H	20.1	20.7	20.6	21.2	21.8	23.0	23.6	23.5	24.1	24.6
12H	4H	19.0	19.8	19.5	20.3	20.8	21.0	21.8	21.4	22.3	22.7
	6H	19.9	20.6	20.4	21.0	21.5	22.3	23.0	22.8	23.4	24.0
	8H	20.2	20.8	20.7	21.3	21.9	22.8	23.4	23.3	23.9	24.4

Maximum UGR = 24.6

POLAR GRAPH



Maximum Candela = 1768.779 Located At Horizontal Angle = 90, Vertical Angle = 1.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (1.5) (Through Max. Cd.)