



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFR G2 24 SEL75 UV FA 935 @1100MA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001588-007A (s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUEDATE] 6/4/2024

[MANUFAC] LumenFocus, LLC

[LUMCAT] FFR G2 24 SEL75 UV FA 935

[LUMINAIRE] Retrofit kit installed in an A.L.P. EL-2x4-23-2 2x4 housing,

[MORE] formed white painted steel reflectors, frosted linear ribbed plastic enclosure.

[LAMP] Two LS3873A8_3500_90R 3500K 64 LED boards

[BALLAST] One KTLD-75-UV-PS1400-54-VDIM-LM2 LED driver set to 1100mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	7936
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	145
Total Luminaire Watts	54.8
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.75 ft
Luminous Width (90-270)	1.75 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	3768	4102	4427
55	3461	4002	4538
65	3100	3973	4814
75	2602	4077	5383
85	1756	3578	3712

IES INDOOR REPORT**PHOTOMETRIC FILENAME : FFR G2 24 SEL75 UV FA 935 @1100MA.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	1000.03	N.A.	12.60
0-30	2110.64	N.A.	26.60
0-40	3434.38	N.A.	43.30
0-60	6054.14	N.A.	76.30
0-80	7739.57	N.A.	97.50
0-90	7935.85	N.A.	100.00
10-90	7676.02	N.A.	96.70
20-40	2434.35	N.A.	30.70
20-50	3800.53	N.A.	47.90
40-70	3633.18	N.A.	45.80
60-80	1685.43	N.A.	21.20
70-80	672.01	N.A.	8.50
80-90	196.27	N.A.	2.50
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	7935.85	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	259.82
10-20	740.21
20-30	1110.61
30-40	1323.74
40-50	1366.18
50-60	1253.58
60-70	1013.42
70-80	672.01
80-90	196.27
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : FFR G2 24 SEL75 UV FA 935 @1100MA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90	93	90	87	89	87	85	83
2	98	89	82	76	95	88	81	75	84	78	74	81	76	72	78	74	70	68
3	89	78	70	63	87	77	69	63	74	67	61	71	65	60	68	63	59	57
4	82	69	60	53	79	68	59	53	65	58	52	63	57	51	61	55	51	48
5	75	62	53	46	73	61	52	46	58	51	45	56	50	45	55	49	44	42
6	69	56	46	40	67	55	46	40	53	45	39	51	44	39	49	43	39	37
7	64	50	41	35	62	50	41	35	48	40	35	47	40	35	45	39	34	32
8	60	46	37	31	58	45	37	31	44	36	31	43	36	31	41	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25	36	30	25	36	30	25	23


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FFR G2 24 SEL75 UV FA 935 @1100MA.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	16.1	17.7	16.4	18.1	18.4	17.7	19.4	18.1	19.7	20.0
	3H	17.8	19.3	18.2	19.6	20.0	20.1	21.6	20.5	21.9	22.3
	4H	18.4	19.9	18.8	20.2	20.6	21.1	22.6	21.5	22.9	23.3
	6H	18.9	20.2	19.3	20.6	21.0	22.1	23.4	22.5	23.8	24.1
	8H	19.0	20.3	19.4	20.7	21.1	22.4	23.6	22.8	24.0	24.4
	12H	19.1	20.3	19.5	20.7	21.1	22.5	23.7	22.9	24.1	24.5
4H	2H	17.0	18.4	17.4	18.8	19.1	18.3	19.7	18.6	20.0	20.4
	3H	19.0	20.2	19.4	20.6	21.0	20.9	22.1	21.3	22.5	22.9
	4H	19.7	20.8	20.2	21.2	21.7	22.1	23.2	22.6	23.6	24.1
	6H	20.3	21.3	20.7	21.7	22.2	23.2	24.2	23.7	24.6	25.1
	8H	20.5	21.4	21.0	21.8	22.3	23.6	24.5	24.1	24.9	25.4
	12H	20.6	21.4	21.1	21.9	22.4	23.8	24.6	24.3	25.1	25.6
8H	4H	20.4	21.3	20.9	21.7	22.2	22.4	23.3	22.9	23.8	24.2
	6H	21.2	21.9	21.6	22.4	22.9	23.7	24.5	24.2	25.0	25.4
	8H	21.4	22.1	21.9	22.6	23.1	24.2	24.8	24.7	25.4	25.8
	12H	21.6	22.2	22.1	22.7	23.3	24.5	25.1	25.0	25.6	26.1
12H	4H	20.5	21.3	21.0	21.8	22.3	22.5	23.3	22.9	23.8	24.2
	6H	21.4	22.1	21.9	22.5	23.0	23.8	24.5	24.3	24.9	25.5
	8H	21.7	22.3	22.2	22.8	23.4	24.3	24.9	24.8	25.4	25.9

Maximum UGR = 26.1

POLAR GRAPH



Maximum Candela = 2752.616 Located At Horizontal Angle = 90, Vertical Angle = 1.5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (1.5) (Through Max. Cd.)