



IES INDOOR REPORT

PHOTOMETRIC FILENAME : EWL S G2 2 HI UV FA 935.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA002568-003A(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 1/3/2025

[MANUFAC] LumenFocus, LLC

[LUMCAT] EWL S G2 2 HI UV FA 935

[LUMINAIRE] Surface or pendant mounted, formed white painted steel housing,

[MORE] formed white painted steel reflector, frosted plastic enclosure with interior

[MORE] linear prisms

[LAMPCAT] One CL116-3500K-R90-A6-CREE G CLASS PRO9 64UP LED board with 64 LEDs.

[BALLAST] One Keystone Technologies KTLD-30-UV-P1050-55-VDIM-LT1 LED driver set at 570mA

[OTHER] 119.9Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4060
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	141
Total Luminaire Watts	28.7
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.18
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.34
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	2.00 ft
Luminous Width (90-270)	0.44 ft
Luminous Height	0.12 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	11996	11517	12166
55	10518	10254	11302
65	8847	8916	10401
75	6650	7464	9457
85	2895	6049	8747

IES INDOOR REPORT
PHOTOMETRIC FILENAME : EWL S G2 2 HI UV FA 935.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	467.69	N.A.	11.50
0-30	985.34	N.A.	24.30
0-40	1598.51	N.A.	39.40
0-60	2790.09	N.A.	68.70
0-80	3544.87	N.A.	87.30
0-90	3710.87	N.A.	91.40
10-90	3589.25	N.A.	88.40
20-40	1130.81	N.A.	27.90
20-50	1756.9	N.A.	43.30
40-70	1641.61	N.A.	40.40
60-80	754.78	N.A.	18.60
70-80	304.75	N.A.	7.50
80-90	166.00	N.A.	4.10
90-110	166.72	N.A.	4.10
90-120	225.24	N.A.	5.50
90-130	271.51	N.A.	6.70
90-150	328.48	N.A.	8.10
90-180	349.08	N.A.	8.60
110-180	182.36	N.A.	4.50
0-180	4059.95	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	121.62
10-20	346.07
20-30	517.64
30-40	613.17
40-50	626.08
50-60	565.50
60-70	450.03
70-80	304.75
80-90	166.00
90-100	93.88
100-110	72.83
110-120	58.53
120-130	46.27
130-140	34.22
140-150	22.75
150-160	13.08
160-170	6.04
170-180	1.49

IES INDOOR REPORT
PHOTOMETRIC FILENAME : EWL S G2 2 HI UV FA 935.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	117	117	117	117	113	113	113	113	106	106	106	100	100	100	94	94	94	91
1	106	101	96	92	102	97	93	89	92	88	85	86	83	81	81	79	77	74
2	96	87	80	74	92	85	78	73	80	74	70	75	71	67	71	67	64	61
3	87	76	68	61	84	74	66	60	70	63	58	66	61	56	62	58	54	51
4	80	68	59	52	77	66	57	51	62	55	49	59	53	48	56	50	46	44
5	73	60	51	45	71	59	50	44	56	48	43	53	46	41	50	45	40	38
6	68	54	45	39	65	53	44	38	50	43	37	48	41	36	45	40	35	33
7	63	49	40	34	61	48	40	34	46	38	33	43	37	32	41	36	31	29
8	58	45	36	31	56	44	36	30	42	35	29	40	33	29	38	32	28	26
9	55	41	33	27	53	40	32	27	38	31	27	37	30	26	35	30	25	23
10	51	38	30	25	49	37	30	25	36	29	24	34	28	24	33	27	23	21

IES INDOOR REPORT
PHOTOMETRIC FILENAME : EWL S G2 2 HI UV FA 935.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise

X=2H	Y=2H	18.2	19.7	18.7	20.2	20.7	20.6	22.1	21.1	22.6	23.1
	3H	19.6	21.0	20.1	21.5	22.0	22.9	24.2	23.4	24.7	25.3
	4H	20.1	21.3	20.6	21.8	22.4	23.9	25.1	24.4	25.7	26.2
	6H	20.3	21.5	20.9	22.0	22.6	24.9	26.1	25.4	26.6	27.2
	8H	20.4	21.5	20.9	22.0	22.6	25.4	26.5	25.9	27.0	27.7
	12H	20.4	21.4	20.9	22.0	22.6	25.9	26.9	26.4	27.5	28.1

UGR Viewed Endwise


4H	2H	19.1	20.4	19.6	20.9	21.5	21.0	22.2	21.5	22.8	23.3
	3H	20.7	21.8	21.3	22.4	23.0	23.5	24.5	24.0	25.1	25.7
	4H	21.3	22.2	21.8	22.8	23.5	24.7	25.6	25.2	26.2	26.8
	6H	21.6	22.5	22.2	23.1	23.7	25.9	26.7	26.4	27.3	28.0
	8H	21.7	22.5	22.3	23.1	23.8	26.4	27.2	27.0	27.8	28.5
	12H	21.7	22.5	22.4	23.1	23.8	27.1	27.8	27.7	28.4	29.1

8H	4H	21.9	22.7	22.5	23.3	23.9	24.8	25.6	25.4	26.2	26.9
	6H	22.4	23.1	23.0	23.7	24.4	26.2	26.9	26.8	27.5	28.2
	8H	22.5	23.2	23.2	23.8	24.5	26.9	27.5	27.5	28.2	28.8
	12H	22.6	23.2	23.3	23.8	24.6	27.7	28.2	28.3	28.9	29.6

12H	4H	22.0	22.8	22.7	23.4	24.1	24.8	25.6	25.4	26.2	26.9
	6H	22.6	23.3	23.3	23.9	24.6	26.2	26.8	26.9	27.4	28.2
	8H	22.9	23.4	23.5	24.0	24.8	27.0	27.5	27.6	28.2	28.9

Maximum UGR = 29.6

POLAR GRAPH



Maximum Candela = 1288.053 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)