



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : EWL S G2 8 SH UV FA 930.IES

### DESCRIPTION INFORMATION (From Photometric File)

[IESNA:LM-63-2002

[TEST] LLIA002568-007A(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 1/3/2025

[MANUFAC] LumenFocus, LLC

[LUMCAT] EWL S G2 8 SH UV FA 930

[LUMINAIRE] Surface or pendant mounted, formed white painted steel housing,  
[MORE] formed white painted steel reflector, frosted plastic enclosure with interior

[MORE] linear prisms

[LAMPCAT] Four CL115-3000K-R90-A5 CREE G CLASS PRO 9 84UP LED boards with 84 LEDs each.

[BALLAST] Two Keystone Technologies KTLD-85-UV-P2300-55-VDIM-LT2 LED drivers set at 1,580mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	20762
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	145
Total Luminaire Watts	143.2
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.20
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	8.00 ft
Luminous Width (90-270)	0.44 ft
Luminous Height	0.12 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	16268	15144	15435
55	14624	13654	14311
65	12700	12023	13152
75	10123	10254	11952
85	5487	8549	10977

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : EWL S G2 8 SH UV FA 930.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	2372.02	N.A.	11.40
0-30	5006.35	N.A.	24.10
0-40	8138.81	N.A.	39.20
0-60	14258.06	N.A.	68.70
0-80	18139.74	N.A.	87.40
0-90	18982.2	N.A.	91.40
10-90	18366.12	N.A.	88.50
20-40	5766.78	N.A.	27.80
20-50	8977.46	N.A.	43.20
40-70	8436.07	N.A.	40.60
60-80	3881.68	N.A.	18.70
70-80	1564.86	N.A.	7.50
80-90	842.46	N.A.	4.10
90-110	847.93	N.A.	4.10
90-120	1149.97	N.A.	5.50
90-130	1388.94	N.A.	6.70
90-150	1679.08	N.A.	8.10
90-180	1779.59	N.A.	8.60
110-180	931.66	N.A.	4.50
0-180	20761.79	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	616.08
10-20	1755.95
20-30	2634.32
30-40	3132.46
40-50	3210.67
50-60	2908.57
60-70	2316.82
70-80	1564.86
80-90	842.46
90-100	474.38
100-110	373.55
110-120	302.03
120-130	238.97
130-140	175.70
140-150	114.44
150-160	63.76
160-170	29.05
170-180	7.70

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : EWL S G2 8 SH UV FA 930.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	117	117	117	117	113	113	113	113	106	106	106	100	100	100	94	94	94	91
1	106	101	96	92	102	97	93	89	92	88	85	86	83	81	81	79	77	74
2	96	87	80	74	92	85	78	72	80	74	70	75	71	67	71	67	64	61
3	87	76	68	61	84	74	66	60	70	63	58	66	61	56	62	58	54	51
4	80	68	59	52	77	66	57	51	62	55	49	59	53	48	56	50	46	44
5	73	60	51	44	71	59	50	44	56	48	43	53	46	41	50	44	40	38
6	68	54	45	39	65	53	44	38	50	43	37	48	41	36	45	40	35	33
7	63	49	40	34	60	48	40	34	46	38	33	43	37	32	41	36	31	29
8	58	45	36	30	56	44	36	30	42	35	29	40	33	29	38	32	28	26
9	55	41	33	27	53	40	32	27	38	31	26	37	30	26	35	29	25	23
10	51	38	30	25	49	37	30	24	35	29	24	34	28	23	33	27	23	21


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : EWL S G2 8 SH UV FA 930.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	19.2	20.7	19.7	21.2	21.7	21.5	23.0	22.0	23.5	24.0
	3H	20.6	21.9	21.1	22.5	23.0	23.8	25.2	24.4	25.7	26.2
	4H	21.1	22.3	21.6	22.8	23.4	24.9	26.2	25.4	26.7	27.3
	6H	21.3	22.5	21.9	23.0	23.6	26.0	27.1	26.5	27.7	28.3
	8H	21.4	22.5	21.9	23.0	23.6	26.5	27.6	27.1	28.2	28.8
	12H	21.4	22.4	21.9	23.0	23.6	27.1	28.2	27.6	28.7	29.3
4H	2H	20.1	21.3	20.6	21.9	22.4	21.9	23.2	22.4	23.7	24.3
	3H	21.7	22.8	22.3	23.4	24.0	24.5	25.5	25.0	26.1	26.7
	4H	22.3	23.2	22.8	23.8	24.5	25.7	26.7	26.3	27.2	27.9
	6H	22.6	23.5	23.2	24.1	24.7	26.9	27.8	27.5	28.4	29.1
	8H	22.7	23.5	23.3	24.1	24.8	27.6	28.4	28.2	29.0	29.6
	12H	22.8	23.5	23.4	24.1	24.8	28.3	29.0	28.9	29.6	30.3
8H	4H	22.9	23.7	23.5	24.3	25.0	25.9	26.7	26.5	27.3	27.9
	6H	23.4	24.1	24.1	24.7	25.4	27.3	28.0	27.9	28.6	29.3
	8H	23.6	24.2	24.2	24.8	25.5	28.0	28.7	28.7	29.3	30.0
	12H	23.7	24.2	24.3	24.8	25.6	28.9	29.5	29.6	30.1	30.8
12H	4H	23.1	23.8	23.7	24.4	25.1	25.9	26.6	26.5	27.2	27.9
	6H	23.7	24.3	24.3	24.9	25.6	27.3	27.9	28.0	28.5	29.3
	8H	23.9	24.4	24.5	25.1	25.8	28.1	28.7	28.8	29.3	30.1

Maximum UGR = 30.8

POLAR GRAPH



Maximum Candela = 6530.959 Located At Horizontal Angle = 90, Vertical Angle = 2  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (2) (Through Max. Cd.)